



## **TAMIL NADU ELECTRICITY REGULATORY COMMISSION**

### **Amendments to the Tamil Nadu Electricity Supply Code**

**Notification No. TNERC/SC/- ..... Dated xx.04.2023**

**(Comments invited by 26.05.2023)**

The following draft of amendments to the Supply Code Regulations, 2004, which is proposed to be made in exercise of the powers conferred by section 181 read with section 50 of the Electricity Act, 2003 (Central Act 36 of 2003) and all other powers enabling it in this behalf, is hereby published for information of all persons likely to be affected thereby, as required by subsection (3) of section 181 of the said Act.

Notice is hereby given that the draft amendment will be taken into consideration after expiry of thirty days from the date of publication of this Notification in the TNERC website and that any objection or suggestion, which may be received from any person before the expiry of the aforesaid period, will be considered by the Commission.

Objection or suggestion, if any, should be addressed in duplicate along with a soft copy to the Secretary, Tamil Nadu Electricity Regulatory Commission, 4th Floor, SIDCO Corporate Office Building, Thiru Vi Ka Industrial Estate, Guindy, Chennai-600032 (email id- [tnerc@nic.in](mailto:tnerc@nic.in)).

## AMENDMENTS

**In the said Regulations,-**

**1a. In Regulation 2, after clause (s), the following clause shall be inserted, namely: -**

*“(t) “Unauthorised use of electricity” has the same meaning as assigned to it under section 126 of the Act. The unauthorised use of electricity dealt under section 135 of the Act is applicable only to the theft of energy / illegal restoration of supply.”*

**1b. In Regulation 2, at the end, the existing expression**

*“Words and expressions used in this Code but not defined either in this Code or the Act or the General Clauses Act 1897 (Central Act 10 of 1897) shall have the same meanings as understood in the Engineering and Commercial circles.”*

**shall be substituted with the following, namely:-**

*“Words and expressions used in this Code but not defined either in this Code or the Act or the Electricity (Rights of Consumer Rules), 2020 or any other Regulations of the Commission or the General Clauses Act 1897 (Central Act 10 of 1897) shall have the same meanings as commonly understood in the Engineering and Commercial parlance.”*

**2. In Regulation 3, in sub-regulation (3), the term ‘extra’ shall be omitted: -**

**3. In Regulation 4, in sub-regulation (2), after clause (xvi), the following shall be inserted, namely: -**

*“(xvii) Charges for periodical inspection for installation testing other than routine inspections like mass raid etc.,*

*(xviii) Charges for temporary disconnection at the request of consumer.”*

**4a. In Regulation 5, the existing clause (i) and (ii) of sub-regulation (2) shall be substituted with the following, namely: -**

**2) Excess demand charge:**

*Whenever the consumer exceeds the sanctioned demand, excess demand charge shall be:—*

“(i) In the case of HT supply, the maximum demand charges for any month shall be based on the kVA demand recorded in that month or such percentage of sanctioned demand as may be declared by the Commission from time to time whichever is higher. The exceeded demand shall alone be charged at double the normal rate.

(ii) In case of LT supply,

(a) Except agricultural and agricultural allied category of services, the excess demand charges shall be applicable for all other category of services irrespective of quantum of load.

(b) For all services covered under applicability of excess demand charges, the licensee shall install meters with demand recording facility to bring the consumer under the scope of excess demand chargeable category. No excess demand charge is leviable till such time the licensee installs meter with demand recording facility and brings the consumer under the scope of excess demand chargeable category.

(c) The excess demand charges shall be at the rate of percentage of ‘total energy charges’ for every kW or part thereof over and above the sanctioned demand, as tabulated below:

**Table:**

<b>Sanctioned Demand</b>	<b>Recorded demand over and above the sanctioned demand</b>	<b>First occurrence</b>	<b>Second occurrence</b>	<b>Third occurrence</b>	<b>Fourth &amp; subsequent occurrences</b>
Upto 112 kW	Upto 112kW.	1%	1%	1%	Should have been regularised after 3 <sup>rd</sup> occurrence.
	Above 112 kW & upto 150kW.	1.5%	1.5%	3%	Should have been regularised after 3 <sup>rd</sup> occurrence and all the conditions stipulated under Supply Code regulation 3(1)(b) shall be applicable.
Above 112 kW and upto 150 kW	Upto 150 kW.	1%	1%	1%	Should have been regularised after 3 <sup>rd</sup> occurrence.
	Above 150 kW.	1%	1.5%	3%	10% (until HT service is availed)

*Explanation:*

1. *'Total energy charges' means the total charges of electricity supplied which includes both fixed/demand charges and energy charges.*
2. *The first, second, third, fourth and consequent occurrences specified in the above table mean the occurrences within a period of 12 months preceding the date of regular assessment of any billing cycle. Counting of occurrences shall begin only from the first occurrence that has taken place within the said period of twelve months irrespective of number of recurrences happened in the past before the commencement of this period.*
3. *The licensee shall issue a notice to the consumer pursuant to the first and second occurrences of excess demand over and above the sanctioned demand, advising the consumer to control the recorded demand within the sanctioned demand. The notice shall also contain the entire terms and conditions of this sub-regulation to create awareness to the consumer and to enable him to take remedial measures in time.*
4. *The consumer shall take timely remedial measures to control the recorded demand within the sanctioned demand and avoid recurrence.*
5. *On third occurrence, besides billing excess demand charges, the existing demand sanction shall be revised to the level of recorded demand during third occurrence.*  
*The development charges and security deposit pertaining to the quantum of demand exceeded shall be included in the next bill as follows:*
  - (a) Development charges pertaining only to the quantum of demand exceeded*
  - (b) The security deposit required over and above available deposit and accrued interest there on.*
6. *Only the development charges and security deposit which are in force, at the time of occurrence of excess demand shall be payable.*
7. *If the recorded demand exceeds 150kW for the third time in the period of twelve months, the licensee besides collecting excess demand charges shall issue 'one month notice' to the consumer for conversion of LT service into HT service indicating all relevant charges to be paid for HT service connection for the level of recorded demand during third occurrence.*
8. *In all services which are newly to be brought under the scope of Excess Demand charges consequent to this sub-regulation, the excess MD charges shall be applicable only after the date of notification of this order or the date of installation of meter with MD recording facility, whichever is later.*

9. *For the cases where MD had exceeded the sanctioned demand in the past, prior to this notification and settled back within the level of originally sanctioned demand for a continuous period of twelve months as on the date of this notification but remaining unregularised, may be allowed to continue with the original sanctioned demand.”*

**4b. In regulation 5, in sub-regulation (5), the existing clause (v) shall be substituted with the following, namely:-**

*“(v) Where, on review, the amount of Security Deposit held is found to be in excess of the requirement, the excess shall be adjusted against two future demands for the electricity supplied. Where, after such adjustment in future two demands, there is balance to be refunded, the refund shall be made by cheque or direct credit to the account of consumer under advice to him, if bank account details are provided, before the due date for payment of the third demand. No other documents are required.”*

**4c. In regulation 5, the sub-regulation (12) shall be substituted with the following, namely:-**

*“(12) Application Registration Charges:*

*The Licensee shall collect application registration charges from the applicants for the following, at the rates specified by the Commission from time to time.*

- (a) Application for new HT/LT services.*
- (b) Application for addition/reduction of demand/load in respect of HT and LT Services.*
- (c) Application for temporary service.*
- (d) Application for conversion of a service from LT to HT and vice versa.*
- (e) Application for shifting of HT / LT services under Deposit Contribution Works basis.*
- (f) Application for shifting of HT/LT lines/ structures/ equipment under Deposit Contribution Works basis.*
- (g) Application for change of tariff.*
- (h) Application for repair or replacement of Board's properties damaged due to dashing of vehicles etc., by the third parties chargeable under Deposit Contribution Works basis.”*

**5a. In regulation 7, the sub-regulations (1), (2), (3) & (3A) shall be substituted with the following, namely:-**

*“(1) No new service connection shall be given without meter. For all new LT service connections, the Licensee shall install meters with demand recording facility.*

*(2) At the time of seeking a new connection / temporary service connection, the applicant shall have the option either to purchase a meter on his own as per prescribed standards, specifications and relevant Regulations or require that meter to be supplied by the Distribution Licensee. Unless the consumer elects to purchase his own meter, the Licensee shall provide meters complying statutory standards and relevant Regulations and may require the consumer to give adequate security for the price of the meter and pay the hire charges there for. Where the consumer elects to purchase his own meter, the Licensee shall ensure that such meter complies with relevant standards, specifications and Regulation. Meters purchased by the consumer shall be tested, installed and sealed by the Licensee. A tracking and recording software for all new seals shall be provided by the manufacturer of the meter so as to track total movement of seals starting from manufacturing, procurement, storage, record keeping, installation, series of inspections, removal and disposal. Only the patented seals (seal form the manufacturer who has official right to manufacture the seal) shall be used. The consumer shall claim the meter purchased by him as his asset only after it is permanently removed from the system of the Licensee.*

*The Licensee shall publish and keep on updating on their web-portal about type, single phase / three phase capacity rating with respect to demand applied, specification along with the list of approved meter manufacturers and information of the places from where the consumers can purchase those meters. It shall cover all categories of LT, LT CT, HT , Bidirectional metering, solar generation, pre paid metering, ToD metering etc., on a permanent basis without any restriction in terms of period of duration for purchase, quantity of meters to be purchased by a division / circle etc.,*

*(3) The Licensee shall endeavor to provide smart pre-payment meter or pre-payment meter in a phased manner giving priority to services of higher consumption/revenue. All Central/State Govt. and local body services shall be provided with smart meters with facility of pre-payment mode. In areas which do not have communication network, pre payment meters shall be provided.*

*For temporary supply, pre-payment meters (Rechargeable card Model) shall be provided. The pre-payment meter shall comply with relevant standards, specifications and Regulations. For pre-payment meter, payment of security deposit is not required.*

*(3A) In case of open access consumer, the Interface meters with facilities to record export and import of energy and other parameters depending upon tariff requirement shall be provided both at the generator and consumer ends and other required locations. The meters shall comply with relevant standards and specifications in accordance with the Central Electricity Authority (Installation and Operation of Meters) Regulations, 2006, as amended from time to time.”*

**5b. In regulation 7, in sub-regulation (7), the existing clause (ii) shall be substituted with the following, namely: -**

*“(ii) when the above formula is made applicable for the LT services of more than 112kW in accordance with sub-regulation 3(1)(b) of this Code or the capacity of the feeding transformer is more than capacity required to feed the contracted demand of the individual consumer, the kVA rating of the transformer represented as ‘C’ in the above formula shall be limited to the lower capacity of the transformer of available rating being used by the Licensee which is actually required to meet the quantum of contract demand of the individual consumer.*

*The transformer loss arrived as above, shall be added to the energy consumption, even when the recorded energy consumption is nil.”*

**5c. In regulation 7, the existing sub-regulation (9) shall be substituted with the following, namely:-**

*“(9) If a consumer considers that the meter is defective or meter readings not being commensurate with his consumption of electricity, he may apply to the Licensee to have a special test carried out at Licensees’ lab. The test shall be carried out by Licensee within 30 days and the cost of such a test shall be borne by the Licensee or the consumer according to the result of such test as to whether the meter is defective or correct.*

*The distribution licensee shall convey the date and time for such test to the consumer for his presence during testing. After testing, the Licensee shall give a copy of test report to the consumer duly signed by both the Licensee and the consumer, and retain one copy as acknowledgment. However, if the consumer opts not to be present at the site for testing, the distribution licensee shall carry out such testing and send copy of the report to the consumer, If the consumer disputes the results of such testing and demands re-testing by third party by accepting to bear the charges for such test the Licensee shall arrange the testing at third party testing Lab accredited by NABL from the list of third party testing agencies approved by the Commission. If it is established that the errors are beyond the specified limits and contrary to the results of the test*

*performed by the Distribution Licensee, the cost of carrying out such test already paid by the consumer shall be reimbursed by the Distribution Licensee. However in case it is established that the results of the test are the same as the results of the test performed by the Distribution Licensee, the cost of carrying out such test shall stand to be borne by the consumer. The meter data and test results shall be issued to the consumer and said results are final and binding on both the consumer and distribution licensee.*

*The list of third party agencies approved by the Commission shall be available in various offices and the website of the distribution licensee.”*

**5d. In regulation 7, the existing sub-regulation (10) shall be substituted with the following, namely:-**

***“(10) The procedure to be followed for replacement of defective/ damaged/ burnt meter shall be as follows:***

*(i) It is the responsibility of the Licensee to replace all defective meters belonging to the Licensee at his cost. The meter with defects such as stoppage of recording, stoppage of display, damage to seal, burning or damage to meter etc either on consumers complaint or upon inspection by the Distribution Licensee shall be replaced within the duration as specified by the Commission and restore supply through a new meter. The released defective meter shall be tested within 30 days in licensee’s lab. Wherever feasible, the data shall be downloaded. The records of all defective meters shall be accompanied with allied documentation of such test results. The important data downloaded such as meter reading and other data relevant to billing shall be documented in the consumer ledger. No defective meter shall be handed over to stores without testing in licensee’s lab.*

*(ii) Since the safe custody of the meter is the consumer’s responsibility, replacement of meter due to damages shall be at the cost of consumer.*

*(iii) If after investigation, it is found that the meter has become defective or burnt due to reasons attributable to the consumer, the cost of new meter and other applicable charges shall be recovered from the consumer through subsequent bills. No fee shall be charged from the consumer at the time of reporting by consumer or being noticed by licensee that the meter is defective or burnt.*

*Besides the said charges for replacement of defective/ burnt meter, necessary bill revision for the period of defect or inaccurate recording of consumption , shall be made as per provisions of this Code and the excess or deficit charges shall be adjusted*



*in the subsequent bills with due intimation to the consumer in writing along with test results and working sheet.*

*Sufficient rolling stock of meter shall be maintained in every section offices of the Licensee for timely replacement of defective meters.*

*(iv) When the meter is owned by the consumer and becomes defective / damaged or burnt due to the fault of the consumer, it is the responsibility of the consumer to replace the meter by a healthy one, if he elects to continue to have his own meter. Otherwise the Licensee shall replace the meter, collect the specified deposits/ applicable Charges from the consumer.”*

**5e. In regulation 7, after sub-regulation (10), the following sub-regulation shall be inserted, namely:-**

*“(11) In case of single phase meters, the consumer shall ensure there is no common neutral or phase or looping of neutral or phase of two or more consumers on consumer side wiring. If such common neutral or phase or looping of neutral or phase comes to the notice of the Licensee or if the earth leakage indication is displayed in the meter, the Licensee shall inform the consumer in writing advising him to rectify the defect to ensure proper recording of consumption.”*

**6a. In regulation 8, after sub-regulation (2), the following sub-regulation (3) shall be inserted, namely: -**

*“(3) The meter shall be read at least once in every billing cycle in urban as well as rural areas by an authorized representative of the distribution licensee. Services of all status such as existing services, newly released services during previous billing cycle, service remaining under disconnection etc., shall be covered in the regular assessment of such periodicity. In case of smart meters, the meters shall be read remotely at least once in every billing cycle and in case of other pre-payment meters; the meters shall be read by an authorized representative of the distribution licensee at least once in every three months. The data regarding remote assessment and billing shall be made available to the consumer, through website or mobile App or SMS, etc. Consumers having smart pre-payment meters may also be given the data access for checking their consumption.”*

**6b. In regulation 8, the existing sub-regulation (4), shall be omitted.**

**6c. In regulation 8, the existing sub-regulation (5), shall be substituted with the following, namely:-**

*“In case of LT services, after taking the meter readings, the particulars of meter readings, energy consumption and charges payable shall be incorporated in the consumer meter card.*

*Wherever the particulars of meter readings, energy consumption, charges payable and last date for payment etc., are sent to the consumer through SMS and Mail to the registered mobile number and e-mail id respectively, such communication shall also be construed as Bill-cum-Notice in relation to the provisions contained under Regulations 8,13 and 14 of this Code.”*

**6d. In regulation 8, the existing sub-regulation (6), shall be substituted with the following, namely:-**

*“(6) Procedure of generation and issue of billing:*

*(a) Payment for energy supplied shall be made by the consumer according to the meter readings referred to above and on delivery of a bill therefor in the case of High Tension consumers and incorporation of current consumption charges in the consumer meter card or assessment slip in the case of Low Tension consumers. In case of pre-payment metering, the distribution licensee shall issue the bill, to the consumer, on his request.*

*Pre-payment meters shall be designed to automatically cut off supply when the amount credited is exhausted. This shall however not be treated as a disconnection and the supply will be resumed whenever the meter is recharged.*

*(b) The distribution licensee shall intimate the consumer about despatch of bill through SMS, immediately after the despatch in case of HT services and within a period of not more than four working days from the date of the assessment in case of LT services. The intimation shall consist of the details of bill amount and the due date for payment.*

*The distribution licensee shall also upload the bill on its website on the day of bill generation. The billing and payment details of minimum last one year for all consumers shall be made available on the licensee’s website.*

*(c) The distribution licensee shall issue the first bill in the same billing month for HT, LT CT services and temporary services. For other services the first bill shall be issued preferably in the same billing month but not exceeding two billing months from the date of effecting a new connection where post payment meters are installed.*

*(d) In case the consumer does not receive the first bill within such period or any regular bill in subsequent periods, he shall complain in writing to the distribution licensee and the distribution licensee shall issue the bill within seven days. The consumer can also get his billing details from Licensee's website.*

*(e) The consumer is equally responsible to make the payment promptly and regularly for the electricity consumed by him from the Licensee.*

*(f) The distribution licensee shall not generate more than two provisional bills for a consumer during one financial year and if the provisional billing continues for more than two billing cycles except under extraordinary situation due to force majeure, the consumer may refuse to pay the dues until bill is raised by the distribution licensee as per actual meter reading.*

*(g) The information regarding the authority with whom grievance or complaint pertaining to bill can be lodged shall be provided along with the bill and the same shall also be made available on distribution Licensee's website.*

*(h) In case of vacation of premises, the distribution licensee shall arrange to take a special reading of the meter on receiving the consumer's written request and issue a final bill including all arrears till the date of billing and issue a No-Dues Certificate on receiving final payment, within seven days from the receipt of such payment."*

**7. In regulation 9, after sub-regulation (1), the following shall be inserted, namely:**

*"Revised Test Report (RTR) shall be taken incorporating all relevant details of change in demand except temporary reduction of demand. The date of RTR shall be the date of effect of change in demand. The changes made in respect to meter/metering system such as meter details /CT details / C.T. ratio available / adopted, change in M.F meter/meter box seals etc shall be documented in the RTR clearly. However, for temporary reduction of demand effected on seasonal basis as requested by the consumer without any change in the metering system, the RTR is not necessary.*

*(1A) Dynamic reduction of load to suit the seasonal requirement is applicable to Industries other than IT services covered under IIIB and marriage halls covered under Tariff V. Dynamic reduction of demand shall be effected on application by the consumer. Such application shall be made online in a simple format. No other charges than registration fee is payable. No inspection is necessary. The metering system need not be de-rated for temporary load reduction. The reduction in demand shall take effect from the date of meter reading and MD reset of succeeding assessment following the date of application. Contracted demand shall continue to be unaltered in their Test*

*report and contracted agreement. After the requested period for temporary reduction demand is over, the level of demand shall be resumed automatically to the original contracted demand.*

*The reduction of demand shall be applicable for a minimum of one billing cycle. Reduction of demand is permissible two times in a financial year irrespective of the duration for which reduction of demand is required.*

*In case the level of temporarily reduced demand is exceeded in a billing cycle, the fixed charges for the entire billing cycle shall be payable to the original contracted demand only and not proportionately. Licensee shall enable the application and billing software for seamless processing.”*

**8. In Regulation 10, after existing sub-regulation (5), the following shall be inserted, namely:-**

*“(6) In case of unforeseen constraints on the part of Licensee to carry out the assessment / force-majeure conditions, the Licensee may have the option of allowing the consumer to send the picture of meter display of the respective service connection that indicates the meter reading of billing parameters and the date of such readings, through registered mobile or e-mail to the designated officer of the Licensee.”*

**9a. In Regulation 11, the existing sub-regulation (1) shall be substituted with the following, namely:-**

**“11. Assessment of billing in cases where the meter is defective:**

*(1) Where the meter fixed is found defective or burnt or to have ceased to function and no theft of energy or violation is suspected, the quantity of electricity supplied during the period when the meter was defective, shall be assessed based on the data downloaded through CMRI from the defective meter and scrutiny of those data , load curve etc., besides taking into consideration of site condition to corroborate the assessment so made. Wherever such downloading of data could not be done, the reason for not getting the meter tested or the reason for not downloading the data from the defective or burnt meter shall be recorded and signed by the designated authority by the Licensee. Wherever the data could not be downloaded, the quantity of electricity supplied during the period when the meter was defective, shall be assessed as mentioned hereunder.”*

**9b. In Regulation 11, at the end of sub-regulation (6), the following expression shall be inserted, namely:-**

*“In all above cases, the relevant test results and clear working sheet indicating the basis of computation of billing for the back period, the period during which the meter was found defective etc., shall be promptly communicated to the consumer in writing under acknowledgement. “*

**10. The existing Regulation 14A shall be substituted with the following, namely:-**

***“14A Notice to consumers under automated meter reading system-***

*Notwithstanding anything contained in regulations 5,8,13,14 and 16 of this code or any provision in the Distribution Code, wherever the Licensee implements automated meter reading system through Automated Meter Reading (AMR) Technology/ Advanced Metering Infrastructure (AMI) Technology using smart meters/ any other modern technology using smart meter or computerized billing, the billing details such as, Electricity Consumption, Consumption charges for electricity, the due date of payment, demand for additional Security Deposit, any other demand/information etc., shall be communicated through e-mail or SMS to the registered mobile number/e-mail id or any other electronic mode adopted by the Licensee with prior intimation to the Commission and such communication shall be deemed to be the notice issued for such purposes.*

*For this purpose, all consumers have to register their mobile number/ e-mail id with the Licensee and it is the responsibility of the consumer to ensure the correctness and periodical updation of mobile number and e-mail id, so registered. However, the Licensee has to provide appropriate facility for such verification and updation.”*

**11a. In regulation 15, at the end of sub-regulation (1), the following expression shall be added, namely:-**

*“Consumer shall have option to pay bills online or offline.”*

**11b. In regulation 15, the sub-regulations (2) & (3) shall be substituted with the following, namely:-**

*“(2) All High Tension bills, including those on account of miscellaneous charges, shall be paid within the due date fixed by the Licensee from the date of the bill. The High Tension Consumer shall pay the bills through electronic mode such as RTGS/NEFT/Online money transfer for all payments of more than Rs.1000. Depending on the circumstances, the designated authority of the distribution licensee shall however accept cash payments on special occasions and unavoidable circumstances. If the payment is not received within fifteen days (notice period) from the expiry of the due*

*date allowed for payment, the supply will be disconnected. However the consumer may be allowed extension of time to make payment beyond the expiry of the notice period allowed for payment, on an application made to the designated authority of the Distribution Licensee, subject to the levy of BPSC as specified in this Code.*

*(3) Low Tension consumers shall pay the amount due in cash or online or by money order or by demand draft on local bank, or by cheque drawn on a bank where the Distribution Section Office is located or through electronic payment or collection through bank's branch counters or post office, etc. as stipulated by the distribution licensee. However, local bodies and Railways may issue cheque on the banks situated in the place of their office and the Licensee may claim the collection charges, if any, from such consumers. Payment for amounts exceeding Rs.1000/- (Rupees one thousand only) is preferred by DD / cheque/ online payment. Depending on the circumstances, the designated authority of the distribution licensee shall however accept cash payments also and advise the consumer for future remittances by DD / cheque/online payment."*

**12a. In regulation 17, the existing sub-regulation (7) shall be substituted with the following, namely:-**

*"(7) The licensee shall on receipt of the notice referred to in sub-regulation (3) make such adjustment of the dues due to him from the consumer as may be necessary to clear the dues from the consumer against the security deposit or additional security deposit or any other deposit made by the consumer, and after making such adjustment, refund the balance deposit, if any, to the consumer within three months from the date of expiry of the notice period referred to in sub-regulation (3) by direct credit to the account of consumer under advice to him, if bank account details are provided."*

**12b. In regulation 17, the existing sub-regulation (8) shall be substituted with the following, namely:-**

*"(8)Where any consumer has more than one service connection, if he defaults in the payment of dues relating to any one of the service connections that includes dues pointed out by validated audit, charges due to theft of energy, violation, dues relating to deposit contribution works, etc., the licensee may include such dues in other service connection(s) in the name of the consumer and cause those service connection(s) to be disconnected after issuing proper notice with working sheet and quoting the authority under which such dues are payable, till all the arrears due for all the service connections are paid, notwithstanding the fact that the service connections are covered under separate agreements."*

**13. In regulation 19, the existing sub-regulation (6) shall be substituted with the following, namely:-**

*“(6) The assessment under this section shall be made at a rate equal to twice the tariff applicable for the relevant category for which the load was found to have been misused for the period specified in sub-section (5) excluding the cost of supplied electricity already paid by the consumer for the units/demand recorded in the meter for the period for which such assessment is made. The formula for the assessment is given in Form 8-A in Appendix to this Code.”*

**14a. In regulation 22, the existing sub-regulation (1) shall be substituted with the following, namely:-**

*“(1) The Licensee shall restore the supply to the service immediately and in any case not exceeding six working hours on receipt of electricity charges or such other dues and other charges as applicable.”*

**14b. In regulation 22, in sub-regulation (6), the existing sub-clause (ii) shall be substituted with the following, namely:-**

*“(ii) The authorized Officer of the Licensee may permit such consumer to pay the outstanding in installments and to avail reconnection on receipt of 40% of the total arrears outstanding after closing of account due to the licensee, which include –*

*(a) Arrears on the date of closure of accounts.*

*(b) The applicable BPSC / interest up to the date of payment.*

*(c) The balance 60% of the amount shall be collected in ten monthly installments. In addition to the above, the full amount of Security Deposit adjusted while closing of account shall be collected in one lump sum along with the aforesaid portion of 40% before effecting restoration of supply.*

*Explanation: For the purpose of removal of doubts, it is hereby declared that any tariff minimum collected by the Tamil Nadu Electricity Board prior to the date of publication of the Tamil Nadu Electricity Supply (Amendment) Code, 2006 in the Tamil Nadu Government Gazette, that is to say prior to 21st June 2006 on the basis of sub-regulation (6) as it stood before the said amendment need not be refunded by the Tamil Nadu Electricity Board.”*

**15. In regulation 23, in sub-regulation (AA), in clause (7), the expression,**

“Provided that if the quantum of energy consumption is recorded in the meter installed by the Distribution Licensee in the consumer’s premises, the authorized officer shall arrive such energy consumption as per the assessment formula given in Form 8-A in Appendix to this Code.”

**shall be substituted with the following, namely:-**

*“Provided that Section 135 shall be invoked only for the following cases involving the offence of theft of energy:*

- (i) Cases where the energy is not recorded/ partially recorded in the meter.*
- (ii) Cases of illegal restoration of disconnected services.”*

**16a. In Form-8 of Appendix, in clause I(E), the existing sub-clause ii, shall be substituted with the following, namely:-**

***“ii Assessment of quantum of demand charges in HT service and fixed charges in LT services:***

- (a) For all Service connections, the maximum demand shall be assessed as 75% of the total connected load at the time of inspection subject to a minimum of the sanctioned / contracted demand. A power factor of 0.90 lag for HT and 0.85 lag for LT shall be used for conversion between kVA and kW.*
- (b) Assessment of demand charges for HT services:-  
Twice the appropriate H.T. tariff rate for maximum demand.*
- (c) Assessment of fixed charges for LT services:-  
Twice the appropriate LT tariff rate for fixed charges.”*

**16b. In Form-8 of Appendix, the existing clause II, shall be substituted with the following, namely:-**

***“II. Assessment of quantum of energy consumption and charges in case of illegal restoration of supply to a disconnected service connection shall be as follows:***

- (A) The period of assessment will be for twelve months immediately preceding the date of detection of the illegal restoration of supply or for the period from the date of*



*disconnection of the service connection to the date of detection of the illegal restoration, whichever period is less:*

*(B) The quantum of energy for assessment and computation of assessment charges for illegal restoration of supply shall be as follows:*

*(i) When the meter is healthy: - Units recorded from the date of disconnection of the service connection to the date of detection. The assessment shall be equal to twice the tariff applicable that includes both the energy and demand/fixed charges. The tariff charges for the units/demand recorded in the meter for the period for which the assessment is made shall not be collected. If collected, the same shall be credited to the consumer account.*

*(ii) When the meter is found defective: - Quantum of energy consumed by illegal restoration of energy (U) shall be computed using the formula above given in part I.*

*(C) The assessment shall be at two times the applicable charges of electricity that includes both energy charges and demand/fixed charges.*

*(D) In addition to the above assessment charges, all other procedures laid down under sub-regulation 23 (AA) of this Code including the stipulations in regard to compounding the offence shall be followed.*

*Note: The applicable tariff as specified for assessment is the tariff in force during such period of assessment for all the above cases dealt under FORM 8”.*

**17a. Existing heading expressions under Form 8-A of Appendix of Supply Code shall be substituted with the following, namely:-**

**“FORM 8-A**

**[Refer Regulation 19 (6)]**

**FORMULA TO ASSESS CHARGES TOWARDS UNAUTHORIZED USE OF ELECTRICITY UNDER SECTION 126 OF THE ELECTRICITY ACT 2003.”**

**17b. In FORM 8-A, after clause (iii), the following ‘Note’ shall be inserted, namely:-**

**“Note: The tariff for unauthorized use (d) as specified in the above formulae for assessing the charges is the tariff in force during such period of assessment.**

18. Existing Form 9 of Appendix of Supply Code shall be substituted with the following, namely:-

**“FORM 9**

**[Refer Regulation 23 (AA) (8)]**

*Provisional Assessment order for \*theft of energy/Illegal restoration of supply under section 135/138 of the Electricity Act, 2003.*

<i>From (The Authorised Officer),</i>	<i>To (Full address of the person in whose name the service connection stands (or) occupier (or) enjoyer, etc.)</i>
---	---

*Letter No.....,dated.....*

*Sir,*

*Sub: \*Theft of energy /Illegal restoration of supply – Detected in HT/LT SC  
No.....Tariff....Provisional Assessment Order – Reg.  
Ref: Inspection Report dated .....*

*1.0 On.....(the day, month, year of inspection)  
at.....(time) hours the service connection in SC No.....  
located at Door No....., in SF No..... (Full address of the service  
connection) which is/was in the name of Thiru/Thirumathy ..... \*/and  
its installation being occupied / used by ..... was inspected by  
me in the presence of you/your representative Thiru/Thirumathy  
.....*

*2.0 \*During the inspection it was found that an offence of theft of energy/ Illegal  
restoration of supply has been committed  
.....  
..... (describe the actual mode of theft with details of artificial  
means found in the service/unauthorized reconnection of a disconnected service  
connection). By committing the said offence, you have dishonestly abstracted,  
consumed and used energy with the intention to defraud the licensee.*

*The above said illegal abstraction, consumption and use of energy is punishable under section 135/138 of the Electricity Act 2003.*

**The service connection was disconnected on the date of detection of above offence.**

3.0 The approximate loss caused by you due to dishonest abstraction/illegal restoration of supply is assessed at Rs..... (Rupees .....) in accordance with the regulations of the Tamil Nadu Electricity Supply Code, and a working sheet is enclosed herewith.

4.0 The assessment amount as referred to above shall be paid within 7 working days from the date of receipt of this order.

5.0 If you are desirous of filing objections, if any, against the provisional assessment, you may send your explanation to the address of the undersigned with sufficient proof, within seven days from the date of receipt of this order. You may also choose to appear in person or through an authorised representative with relevant documents for an enquiry before the undersigned within 10 days from the date of receipt of this order.

6.0 You are requested to acknowledge the receipt of this order immediately.

Yours Faithfully,  
(Authorised Officer)

Encl: Copies of

1. Inspection Report
2. Statement Recorded (if any)
3. Mahazar
4. Working sheet as per **FORM 8**

Copy submitted to: .....

Copy to

He is instructed to serve this order to the accused person with dated acknowledgement and send the acknowledgement to this office.

**\* Strike out whichever is not applicable. (If offence is theft of energy, section 135 is applicable, strike out section 138. If the offence is illegal restoration of supply, both section 135 and 138 are applicable.)"**

19. Existing Form 10 of Appendix of Supply Code shall be substituted with the following, namely:-

**“FORM 10**  
**[Refer Regulation 23 (AA) (15)]**

*Final Assessment order for \*theft of energy/Illegal restoration of supply under section 135/138 of the Electricity Act, 2003.*

*From*  
*(The Authorised Officer),*

*To*  
*(Full address of the person in whose name the service connection stands (or) occupier(or) enjoyer, etc.)*

*Letter No.....,dated.....*

*Sir,*

*Sub: \*Theft of energy/Illegal restoration of supply – Detected in HT/LT SC No.....Tariff....- Final Assessment Order - Reg.*

*Ref: 1. Provisional Assessment Order...*

*\*2. Your reply....*

*\*\*\*\*\**

*1.0 \* On.....(the day, month, year of inspection) at..... (time) hours the service connection bearing SC No..... located at Door No....., in SF No..... (Full address of the service connection) which is/was in the name of Thiru/Thirumathy ..... /and its installation being occupied / used by .....was inspected by me in the presence of you/your representative Thiru/Thirumathy .....*

*2.0 \*During the inspection it was found that an offence of theft of energy/Illegal restoration of supply has been committed ..... (describe the actual mode of theft with details of artificial means found in the service/unauthorized reconnection of a disconnected service connection). By committing the said offence, you have dishonestly abstracted, consumed and used energy with the intention to defraud the licensee. The above said illegal abstraction, consumption and use of energy is punishable under section 135/138 of the Electricity Act 2003.*

3.0 \* A provisional assessment was issued to you in the reference cited and you were allowed to file your objections and to appear for a hearing as per the Tamil Nadu Electricity Supply Code.

4.0 \* As you have not made any objection or representation/ On detailed examination and careful consideration of your explanation offered, facts and records furnished in your letter / during the personal hearing, the final order is issued herewith as described below:-

(A reasoned/detailed speaking order to be passed by the Officer concerned after thorough analysis of the theft of electricity noticed, inspection report , explanation offered and the findings, etc., Reference to be made to the materials in support of the claim about the existence of theft, the involvement or the role of the consumer with reference to the said theft of energy, relevant rules and regulations relating to consumers' duty and obligations, submissions made by the accused person in his written reply as well as during his personal hearing, documents/materials submitted by him etc., and reasons for acceptance and rejection of the same ).

5.0 \* The loss caused by you due to above explained theft of energy illegal restoration of supply is finally assessed at Rs.....(Rupees .....) in accordance with the regulations of the Tamil Nadu Electricity Supply Code, and a working sheet is enclosed herewith. This final assessment amount shall be paid within seven working days from the date of receipt of this order.

You are requested to acknowledge the receipt of this order immediately.

Yours Faithfully,

(Authorised Officer)

Encl: Copies of

1. Inspection Report
2. Statement Recorded (if any)
3. Mahazar
4. Provisional Assessment Order.
5. Working sheet as per **FORM 8**

Copy submitted to:

He is instructed to serve the order to the accused person with dated acknowledgement and send the same to this office.

**\* Strike out whichever is not applicable. (If offence is theft of energy, section 135 is applicable, strike out section 138. If the offence is illegal restoration of supply, both section 135 and 138 are applicable.)”**

**20. Existing Form 11 of Appendix of Supply code shall be substituted with the following, namely:-**

**“FORM 11**

**[Refer Regulation 23(AA) (22)]**

*Compounding of offence under section 152 of the Electricity Act, 2003.*

*From*

*To*

*(The Authorized Officer),*

*(Full address of the person  
in whose name the service connection stands  
(or) occupier(or) enjoyer, etc.)*

*Letter No.....,dated.....*

*Sir,*

*Sub: \*Theft of energy / Illegal restoration of supply – Detected in HT/LT SC  
No..... Tariff....- Order on Compounding Amount - Reg.*

*1.0 \*On.....(the day, month, year of inspection)  
at.....(time) hours the service connection No..... located at  
Door No....., in SF No..... (Full address of the service  
connection) which is/was in the name of Thiru/Thirumathy ..... / and  
its installation being occupied / used by .....was inspected by me in the  
presence of you/your representative.....  
Thiru/Thirumathy.....*

*2.0 \*During the inspection it was found that an offence of theft of energy/ Illegal  
restoration of supply has been committed.....  
(describe the actual mode of theft with details of artificial means found in the  
service/unauthorized reconnection of a disconnected service connection). By  
committing the said offence, you have dishonestly abstracted, consumed and used  
energy with the intention to defraud the licensee.*

3.0 The above said illegal abstraction, consumption and use of energy is punishable under section 135 / 138 of the Electricity Act 2003.

4.0 As you have opted for compounding of offence under section 152 of the Electricity Act, 2003, you are requested to pay Rs..... (Rupees.....) towards the compounding of the offence as mentioned above.

Yours Faithfully,

(Authorized officer)

Encl: Working sheet.

Copy to .....

**\* Strike out whichever is not applicable. (If offence is theft of energy, section 135 is applicable, strike out section 138. If the offence is illegal restoration of supply, both section 135 and 138 are applicable.)”**

**21. Existing Form-12 of Appendix of Supply code shall be substituted with the following, namely:-**

**“FORM 12**

**[Refer Regulation 19(A)(4)]**

*Provisional Assessment order for unauthorised use of electricity under section 126 of the Electricity Act, 2003.*

From

To

(The Assessment Officer),

(Full address of the person in whose name the service connection stands (or) occupier (or) enjoyer, etc.)

Letter No.....,dated.....

Sir,

Sub:- Unauthorised use of Electricity detected in HT/LT SC No.....  
Tariff..... – Section 126 of the Electricity Act, 2003 – Issue of  
Provisional Assessment Order - Reg.

Ref:- Inspection Report dated .....

1.0 \*On..... (the day, month, year of inspection) at ..... (time) hours, the electricity service connection No..... located at Door No....., in SF No..... (Full address of the service connection) which is/was in the name of Thiru/Thirumathy ...../and its installation being occupied / used by .....was inspected by me in the presence of you/your representative Thiru/Thirumathy .....

2.0 During the inspection, unauthorised use of electricity was noticed as detailed below:

..... (describe the actual mode of unauthorised use of electricity as per the section 126 of the Act). The above said unauthorised use of electricity is punishable under section 126 of the Electricity Act 2003.

3.0 A copy of the inspection report is enclosed. A copy of the mahazar prepared at your premises and acknowledgement obtained from you / your representative has already been furnished to you / your representative. A copy of the statement recorded and signed by you / your representative is also enclosed.

4.0 You are hereby called upon to remove the cause of unauthorised use of electricity immediately if not done already and confirm the same by written intimation.

5.0 The charges payable by you towards the above unauthorized use of electricity is provisionally assessed at Rs..... as per the sub-sections (5) and (6) of section 126 of the Electricity Act, 2003 and as formulated in FORM 8A of the Supply Code of the Tamil Nadu Electricity Regulatory Commission. The working sheet is enclosed. The amount shall be paid within seven days from the date of receipt of this order, failing which the Service Connection shall become liable to be disconnected.

6.0 If you are desirous of filing objections, if any, against this provisional assessment, you may send your explanation to the address of the undersigned with sufficient proof, within seven days from the date of receipt of this order. You may also choose to appear in person or through an authorised representative with relevant documents for an enquiry before the undersigned within the same duration of seven days.

7.0 If no objection/ representation is received from you against this provisional assessment order within the stipulated period, the final order of assessment shall be passed accordingly.



8.0 You are requested to acknowledge the receipt of this order immediately.

Yours Faithfully,

(Assessment Officer)

Encl: Copies of

- 1. Inspection Report
- 2. Statement Recorded (if any)
- 3. Mahazar
- 4. Working sheet as per **FORM 8A**

Copy submitted to: .....

Copy to:

He is instructed to serve this order to the consumer/occupier/enjoyer with dated acknowledgement and send the acknowledgement to this office.”

**\* Strike out whichever is not applicable.”**

**22. Existing Form-13 of Appendix of Supply code shall be substituted with the following, namely:-**

**“FORM 13**

**[Refer Regulation 19(3) and 19(A)(4)]**

*Final order of Assessment for unauthorised use of electricity under section 126 of the Electricity Act, 2003.*

From

To

(The Assessment Officer),

(Full address of the person in whose name the service connection stands (or) occupier (or) enjoyer, etc.)

Letter No.....,dated.....

Sir,

Sub:- Unauthorised use of Electricity detected in HT/LT SC No.....  
Tariff..... - Section 126 of the Electricity Act, 2003 – Issue of Final Assessment Order - Reg.

Ref:- 1. Inspection Report dated .....

\*2. Your reply.....

1.0 On..... (the day, month, year of inspection) at ..... (time) hours, the electricity service connection No..... located at Door No....., in SF No..... (Full address of the service connection) which is/was in the name of Thiru/Thirumathy ..... / \*and its installation being occupied / used by ..... was inspected by me in the presence of you/your representative Thiru/Thirumathy .....

2.0 During the inspection, unauthorised use of electricity was noticed as detailed below: ..... (describe the actual mode of unauthorised use of electricity as per the section 126 of the Act).

3.0 A provisional Assessment order was issued vide reference (1) cited and you were allowed to file your objections if any and also to appear for a hearing as per Tamil Nadu Electricity Supply Code.

4.0 \* As you have not made any objection or representation/ On detailed examination and careful consideration of your explanation offered in your letter cited in reference (2) and with regard to the facts and records furnished by you, the final order is issued herewith as described below: -

(A reasoned/detailed speaking order to be passed by the Officer concerned after thorough analysis of the unauthorised use of electricity noticed, inspection report, explanation offered and the findings etc., Reference to be made to the materials in support of the claim about the existence of unauthorized use of electricity, the involvement or the role of the consumer with reference to the said unauthorized use of electricity, relevant rules and regulations relating to consumers' duty and obligations, objections made by the consumer in his written reply as well as during his personal hearing, documents/materials submitted by him etc., and reasons for acceptance and rejection of the same ).

5.0 The charges payable by you under sub-sections (5) and (6) of the section 126 of the Electricity Act, 2003 is finally assessed at Rs..... (Rupees .....only). The detailed working sheet is enclosed herewith. The said amount shall be paid within 15 days from the date of receipt of this order, failing which the service connection shall become liable for disconnection on expiry of further fifteen days notice.

6.0 If you choose to prefer an appeal against this order, you may prefer an appeal in Form 6 of the Tamil Nadu Electricity Supply Code to the Appellate authority (Executive Engineer/Superintending Engineer/ Operation .....(address of the appellate authority)) within 30 days from the date of receipt of this order on deposit

of half of the assessment amount with the Licensee as per section 127(2) of the Electricity Act, 2003 along with an appeal fee of Rs.100/- by Demand Draft. The Demand Draft shall be drawn in favour of .....Payable at .....

7.0 You are requested to acknowledge the receipt of this Final assessment order immediately.

Yours Faithfully,

(Assessment Officer)

- Encl: 1. Inspection Report  
2. Statement Recorded (if any)  
3. Mahazar  
4. Provisional Assessment Order.  
5. Working sheet as per **FORM 8A**

Copy submitted to:

He is instructed to serve the order to the accused person with dated acknowledgement and send the same to this office.

**\* Strike out whichever is not applicable.\***

(By order of the Tamil Nadu Electricity Regulatory Commission)

-Sd- 26.04.2023

**(Dr.C.VEERAMANI)**

Secretary,

Tamil Nadu Electricity Regulatory Commission.

## **Explanatory statement**

Taking into considerations of recommendations of the Code Review Panel formed and empowered under Regulation 27 of TNE Supply Code and provisions of Electricity (Rights of Consumers) Rules, 2020 made by the Ministry of Power, Govt. of India, following amendments are required to be made in the existing Regulations of the TNE Supply Code 2004, as emended:

More clarity needs to be brought to the applicability of unauthorized use of electricity and categories of supply, by exclusive definition.

The various category of charges recoverable by the Licensee and Registration charges specified in the Supply Code and Tariff order need to be made consistent with each other.

The excess demand charges require to be made applicable to all categories except agricultural category to bring discipline among users of all categories for better load management, demand control and regulated capacity adequacy in the LT network system and metering mechanism. The allowable frequency of exceeding the demand by the consumer, applicability of charges, quantum of charges, implementing methodology etc., are required to be made more practical to remove existing difficulties of stakeholders.

The provisions relating to purchase of meters by consumers for new and temporary service connection, various obligations of consumer and licensee connected with meter, service wire/cable, meter seals, procedures involved in the challenge test of meters disputing its accuracy as opted by the consumers, time limits, procedures involved in replacement of defective/damaged/burnt meter, loss calculation involved in the LT metering of HT services etc., need to be revised and elaborated, for error-free and effective implementation to ensure prompt service to consumers.

The procedure for assessment, billing, time limits serving of bills and the obligation of Licensee as well as consumers in these areas need to be revised and elaborated for proper billing and better service to the consumer.

The procedure of documentation for the revised demand, need to be made more specific to avoid possible lapse in assessment and billing. The concept of dynamic load reduction is envisaged to reduce the financial burden on the seasonal industries.

The methodology of bill revision in case of meter defects need to be revised, giving priority to the data downloaded from the defective meter for basis for revision.

E-payment needs to be encouraged to avoid hardship to consumer owing to physical mode of payment.

Provision to refund the security deposit to the consumer by direct credit into the consumer's bank account is envisaged.

Avenue for payment of dues to Licensee has to be enlarged by loading all kinds of arrears in other service of the defaulter to ensure timely realization of dues to the Licensee.

The time limit for restoration of supply needs to be specified to ensure prompt service to consumers.

The provisions in regard to unauthorized use of electricity (violation by way of misuse of tariff, unauthorized extension of service etc.,) and theft of electricity need to be made more clearer in line with Commission's order in M.P. No. 28 of 2021 dated 05.05.2022 to stop the continuing misinterpretation of these provisions and resultant hardship to the consumers, due to wrong approach of Licensee officers by booking all violations under provisions of theft of energy.

The Forms relating to computation, issue of show cause/provisional assessment / final assessment/ compounding of offence notices etc., need to be revisited and revamped to be comprehensively in line with the provisions of the Electricity Act, 2003 and Regulations of this Commission.

Accordingly, this amendment seeks to incorporate the above provisions in the Regulations of the Commission.

(By order of the Tamil Nadu Electricity Regulatory Commission)

-Sd- 26.04.2023

**(Dr.C.VEERAMANI)**

Secretary,

Tamil Nadu Electricity Regulatory Commission.

**ANNEXURE**  
**TAMIL NADU ELECTRICITY SUPPLY CODE**

<b>Sl. No.</b>	<b>Existing regulation</b>	<b>Proposed Regulation</b>
1a.	<b>2. Definitions</b>  (a) to (s) xxx	<b>2. Definitions</b>  (a) to (s) xxx  (t) “unauthorised use of electricity” has the same meaning as assigned to it under section 126 of the Act. The unauthorized use of electricity dealt under section 135 of the Act is applicable only to the theft of energy / illegal restoration of supply.
1b.	Words and expressions used in this Code but not defined either in this Code or the Act or the General Clauses Act 1897 (Central Act 10 of 1897) shall have the same meanings as understood in the Engineering and Commercial circles	<i>Words and expressions used in this Code but not defined either in this Code or the Act or the Electricity (Rights of Consumer Rules), 2020 or any other Regulations of the Commission or the General Clauses Act 1897 (Central Act 10 of 1897) shall have the same meanings as commonly understood in the Engineering and Commercial parlance.</i>
2.	<b>3. Categories of supply</b>  (1) xxx  (2) xxx  (3) If the consumer opts for higher levels of voltages for demands less than that specified, the consumer shall bear the extra expenses to be incurred by the licensee to provide supply at such higher voltages.	<b>3. Categories of supply</b>  (1) xxx  (2) xxx  (3) <i>If the consumer opts for higher levels of voltages for demands less than that specified, the consumer shall bear the expenses to be incurred by the licensee to provide supply at such higher voltages.</i>

<p>3.</p>	<p><b>4. Charges recoverable by the Licensee-</b></p> <p>(1) xxx</p> <p>(2) Miscellaneous charges, namely,—</p> <p>(i) Capacitor Compensation charge;</p> <p>(ii) Excess demand charge;</p> <p>(iii) Excess contracted load charge</p> <p>(iv) Belated Payment Surcharge.</p> <p>(v) Additional Security Deposit, when so called upon</p> <p>(vi) Service/line/structure/equipments shifting charges.</p> <p>(a) Charges for dismantling temporarily or permanently.</p> <p>(b) Charges for re-erection in case of temporary dismantling.</p> <p>(vii) Name transfer charge.</p> <p>(viii) Reconnection charge.</p> <p>(ix) Consumer meter card replacement charge.</p> <p>(x) Dishonored cheque service charge.</p> <p>(xi) Meter related charges.</p> <p>(xii) Application Registration charge.</p> <p>(xiii) Service connection charges.</p> <p>(xiv) Excess demand and excess energy charges during Restriction and Control of supply.</p> <p>(xv) Charges for restoration of cheque payment facility.</p> <p>(xvi) Charges for testing of equipments / installations.</p>	<p><b>4. Charges recoverable by the Licensee-</b></p> <p>(1) xxx</p> <p>(2) <i>Miscellaneous charges, namely,—</i></p> <p>(i) <i>Capacitor Compensation charge;</i></p> <p>(ii) <i>Excess demand charge;</i></p> <p>(iii) <i>Excess contracted load charge</i></p> <p>(iv) <i>Belated Payment Surcharge.</i></p> <p>(v) <i>Additional Security Deposit, when so called upon</i></p> <p>(vi) <i>Service/line/structure/equipments shifting charges.</i></p> <p>(a) <i>Charges for dismantling temporarily or permanently.</i></p> <p>(b) <i>Charges for re-erection in case of temporary dismantling.</i></p> <p>(vii) <i>Name transfer charge.</i></p> <p>(viii) <i>Reconnection charge.</i></p> <p>(ix) <i>Consumer meter card replacement charge.</i></p> <p>(x) <i>Dishonored cheque service charge.</i></p> <p>(xi) <i>Meter related charges.</i></p> <p>(xii) <i>Application Registration charge.</i></p> <p>(xiii) <i>Service connection charges.</i></p> <p>(xiv) <i>Excess demand and excess energy charges during Restriction and Control of supply.</i></p> <p>(xv) <i>Charges for restoration of cheque payment facility.</i></p> <p>(xvi) <i>Charges for testing of equipments / installations.</i></p> <p>(xvii) <i>Charges for periodical inspection for installation testing other than routine inspections like mass raid etc.,</i></p> <p>(xviii) <i>Charges for temporary disconnection at the request of consumer.</i></p>
-----------	--	---



4a.	<p><b>5. Miscellaneous charges</b></p> <p>(1) xxx</p> <p>(2) Excess demand charge</p> <p>Whenever the consumer exceeds the sanctioned demand, excess demand charge shall be:—</p> <p>(i) In the case of HT supply, the maximum demand charges for any month shall be based on the KVA demand recorded in that month at the point of supply such percentage of sanctioned demand as may be declared by the Commission from time to time whichever is higher. The exceeded demand shall alone be charged at double the normal rate.</p> <p>(ii) In case of LT supply,</p> <p>(a) “For Domestic and Agricultural category of service, the excess demand charges shall not be applicable.”</p> <p>(b) “For other categories of LT services with contracted demand equal to or less than 18.6 KW (25 HP), the excess demand charges shall not be applicable where the connected load is equal to or less than the contracted demand.</p> <p>Note: For services with contracted demand less than or equal to 18.6 KW (25 HP), whenever the consumer’s connected load exceeds the contracted demand, the licensee shall install meters with demand recording facility and bring the consumer under the scope of excess demand chargeable category. After installation of the meter, if the recorded demand is in excess of</p>	<p><b>5. Miscellaneous charges</b></p> <p>(1) xxx</p> <p>(2) <i>Excess demand charge:</i></p> <p><i>Whenever the consumer exceeds the sanctioned demand, excess demand charge shall be:—</i></p> <p>(i) <i>In the case of HT supply, the maximum demand charges for any month shall be based on the kVA demand recorded in that month or such percentage of sanctioned demand as may be declared by the Commission from time to time whichever is higher. The exceeded demand shall alone be charged at double the normal rate.</i></p> <p>(ii) <i>In case of LT supply,</i></p> <p>(a) <i>Except agricultural and agricultural allied category of services, the excess demand charges shall be applicable for all other category of services irrespective of quantum of load.</i></p> <p>(b) <i>For all services covered under applicability of excess demand charges, the licensee shall install meters with demand recording facility to bring the consumer under the scope of excess demand chargeable category. No excess demand charge is leviable till such time the licensee installs meter with demand recording facility and brings the consumer under the scope of excess demand chargeable category.</i></p>
-----	---	--

contracted demand, the existing demand, shall, after intimation to the consumer, be revised to the level of recorded demand and all relevant charges applicable for extension of additional demand shall be included in the next bill. No excess demand charge is leviable till such time the licensee installs meter with demand recording facility and bring the consumer under the scope of excess demand chargeable category.”

(c) For the remaining LT services other than those service connections covered in (a) and (b) above, when the contracted demand is in excess of 18.6KW (25HP) and for such of those consumers whose contracted demand is less than 18.6 KW (25HP) but opted for having meters with demand recording facility, the excess demand charges shall be -,

**(I) Where the sanctioned demand is less than and upto 112 KW:**

(A) Where the recorded demand does not exceed 112 KW, for every KW or part thereof in excess of the sanctioned demand, at the rate of 1% of the total energy charges.

Explanation: ‘Total energy charges’ shall have the same meaning as the term ‘charges of electricity supplied’ which includes both fixed/demand charges and energy charges.

(B) Where the recorded demand exceeds 112 KW, for every KW or part thereof in excess of sanctioned demand:-

- at the rate of 1% of the charges for

(c) The excess demand charges shall be at the rate of percentage of ‘total energy charges’ for every kW or part thereof over and above the sanctioned demand, as tabulated below:

**Table:**

Sanctioned Demand	Recorded demand over and above the sanctioned demand	First occurrence	Second occurrence	Third occurrence	Fourth & subsequent occurrences
Upto 112 kW	Upto 112kW.	1%	1%	1%	Should have been regularised after 3 <sup>rd</sup> occurrence.
	Above 112 kW & upto 150kW.	1.5%	1.5%	3%	Should have been regularised after 3 <sup>rd</sup> occurrence and all the conditions stipulated under Supply Code regulation 3(1)(b) shall be applicable.
Above 112 kW and upto 150 kW	Upto 150 kW.	1%	1%	1%	Should have been regularised after 3 <sup>rd</sup> occurrence.
	Above 150 kW.	1%	1.5%	3%	10% (until HT service is availed)

<p>electricity supplied for every KW or part thereof upto 112 kW;</p> <ul style="list-style-type: none"><li>- and at the rate of 1.5% for every KW or part thereof over and above 112 KW for the first two occurrences;</li><li>- and for the third occurrence, at the rate of 3% for every KW or part thereof over and above 112 KW;</li><li>- and thereafter, that is the fourth &amp; subsequent occurrences at the rate of 10% for every KW or part thereof over and above 112 KW.</li></ul> <p><b>(II) Where the sanctioned demand is above 112 KW but less than or equal to 150 KW:</b></p> <p><b>(A)</b> Where the recorded demand does not exceed 150 KW, for every KW or part thereof in excess of the sanctioned demand, at the rate of 1% of the charges of electricity supplied. The 'charges of electricity supplied' is the fixed/demand charges and energy charges as per proviso to clause (b) of sub-regulation (1) of regulation 3 of this code.</p> <p><b>(B)</b> Where the recorded demand exceeds 150 KW, for every KW or part thereof in excess of sanctioned demand:-</p> <ul style="list-style-type: none"><li>- at the rate of 1% of the charges for electricity supplied for every KW or part thereof upto 150 kW</li><li>- and at the rate of 1.5% for every KW or part thereof over and above 150 KW for the first two occurrences</li><li>- and for the third occurrence, at the rate of 3% for every KW or part thereof over and above 150 KW</li></ul>	<p><i>Explanation:</i></p> <ol style="list-style-type: none"><li>1. 'Total energy charges' means the total charges of electricity supplied which includes both fixed/demand charges and energy charges.</li><li>2. The first, second, third, fourth and consequent occurrences specified in the above table mean the occurrences within a period of 12 months preceding the date of regular assessment of any billing cycle. Counting of occurrences shall begin only from the first occurrence that has taken place within the said period of twelve months irrespective of number of recurrences happened in the past before the commencement of this period.</li><li>3. The licensee shall issue a notice to the consumer pursuant to the first and second occurrences of excess demand over and above the sanctioned demand, advising the consumer to control the recorded demand within the sanctioned demand. The notice shall also contain the entire terms and conditions of this sub-regulation to create awareness to the consumer and to enable him to take remedial measures in time.</li><li>4. The consumer shall take timely remedial measures to control the recorded demand within the sanctioned demand and avoid recurrence.</li><li>5. On third occurrence, besides billing excess demand charges, the existing demand sanction shall be revised to the level of recorded demand during third occurrence.</li></ol> <p><i>The development charges and security deposit pertaining to the quantum of</i></p>
---	---

and thereafter, that is the fourth and subsequent occurrences at the rate of 10% for every KW or part thereof over and above 150 KW

**(III) Revision of sanctioned demand for consumers with sanctioned demand of 112 KW and below, change over to LT category of above 112 KW but less than or equal to 150 KW/HT category :**

For consumers with a sanctioned demand of 112KW and below, where the recorded demand exceeds the sanctioned demand for the second and subsequent times,-

(A) In case the recorded demand **has not exceeded 112 KW**, the existing load sanction shall, after intimation to the consumer, be revised within one month of the second occurrence to the level of maximum recorded demand and all the relevant charges applicable to the additional load shall be included in the next bill .

(B) In case the recorded demand **has exceeded 112 KW** but less than or equal to 150 KW, the existing load sanction shall be revised upto the level of maximum recorded demand subject to acceptance of the conditions in the proviso to clause (b) of sub-regulation (1) of Regulation 3 on payment of all relevant charges applicable. If, however, the consumer does not opt to switch over to LT category limit of 150 KW under the proviso to clause (b) of sub –regulation (1) of regulation 3, the existing load sanction shall, after intimation to the consumer, be revised within one month of the second occurrence, to the level of 112 KW and all relevant charges applicable to the additional load shall be included in the next bill; For the third and subsequent occurrences of recorded demand exceeding the sanctioned demand of

*demand exceeded shall be included in the next bill as follows:*

- (a) Development charges pertaining only to the quantum of demand exceeded*
- (b) The security deposit required over and above available deposit and accrued interest there on.*

- 6. Only the development charges and security deposit which are in force, at the time of occurrence of excess demand shall be payable.*
- 7. If the recorded demand exceeds 150kW for the third time in the period of twelve months, the licensee besides collecting excess demand charges shall issue 'one month notice' to the consumer for conversion of LT service into HT service indicating all relevant charges to be paid for HT service connection for the level of recorded demand during third occurrence.*
- 8. In all services which are newly to be brought under the scope of Excess Demand charges consequent to this sub-regulation, the excess MD charges shall be applicable only after the date of notification of this order or the date of installation of meter with MD recording facility, whichever is later.*
- 9. For the cases where MD had exceeded the sanctioned demand in the past, prior to this notification and settled back within the level of originally sanctioned demand for a continuous period of twelve months as on the date of this notification but remaining unregularised, may be allowed to continue with the original sanctioned demand.*

	<p>112 KW, the licensee shall issue one month's notice for conversion of LT service to HT service indicating all relevant charges to be paid for a HT service connection for the level of recorded demand.</p> <p><b>(IV) Revision of sanctioned demand for consumers with sanctioned demand above 112 KW but less than or equal to 150 KW, conversion to HT category:</b></p> <p>For consumers with a <b>sanctioned demand above 112 KW but less than or equal to 150 KW</b>, where the recorded demand exceeds the sanctioned demand for the second and subsequent times,-</p> <p>(A) In case the recorded demand <b>has not exceeded 150 KW</b>, the existing load sanction shall, after intimation to the consumer, be revised within one month of the second occurrence to the level of maximum recorded demand and all the relevant charges applicable to the additional load shall be included in the next bill .</p> <p>(B) In case the recorded demand has <b>exceeded 150 KW</b>, the existing load sanction shall, after intimation to the consumer, be revised within one month of the second occurrence, to the level of 150 KW and all relevant charges applicable to the additional load shall be included in the next bill. If, however, the recorded demand has exceeded 150 KW for the third or more number of times, the licensee shall issue one month's notice for conversion of LT service to HT service indicating all relevant charges to be paid for a HT service connection for the level of recorded demand.</p> <p><i>(iii) to (v)</i>                      xxx</p>	<p><i>(iii) to (v)</i>                      xxx</p>
--	---	---

<p>4b.</p>	<p>(3) to (4) xxx</p> <p>(5)(v)Where, on review, the amount of Security deposit held is found to be in excess of the requirement, the excess shall be adjusted against two future demands for the electricity supplied. Where, after such adjustment in future two demands, there is balance to be refunded, the refund shall be made by cheque before the due date for payment of the third demand. Where a request is made by the consumer to adjust the excess security deposit above two future demands, the distribution licensee shall adhere to such requests.</p> <p>(6) to (11) xxx</p>	<p>(3) to (4) xxx</p> <p><i>(5)(v)Where, on review, the amount of Security deposit held is found to be in excess of the requirement, the excess shall be adjusted against two future demands for the electricity supplied. Where, after such adjustment in future two demands, there is balance to be refunded, the refund shall be made by cheque or direct credit to the account of consumer under advice to him, if bank account details are provided, before the due date for payment of the third demand. No other documents are required.</i></p> <p>(6) to (11) xxx</p>
<p>4c.</p>	<p><b>(12) Application Registration Charge</b></p> <p>The Licensee shall collect application registration charges from the applicants for the following, at the rates specified by the Commission from time to time.</p> <p>(a) Application for new HT/LT services.          (b) Application for addition/ reduction of demand/load in respect of HT and LT Services.          (c) Application for temporary service.          (d) Application for conversion of a service from LT to HT and vice versa.          (e)Application for shifting of HT/LT</p>	<p><b><i>(12) Application Registration Charges:</i></b></p> <p><i>The Licensee shall collect application registration charges from the applicants for the following, at the rates specified by the Commission from time to time.</i></p> <p><i>(a) Application for new HT/LT services.          (b) Application for addition / reduction of demand / load in respect of HT and LT Services.          (c) Application for temporary service.          (d) Application for conversion of a service from LT to HT and vice versa.          (e) Application for shifting of HT / LT services</i></p>

	<p>services.</p> <p>(f) Application for shifting of lines / structures/ equipments under Deposit Contribution Works for LT/HT.</p> <p>(g) Application for change of tariff.</p> <p>(h) Application for replacement of defective meters.</p>	<p><i>under Deposit Contribution Works basis.</i></p> <p><i>(f) Application for shifting of HT/LT lines/ structures/ equipment under Deposit Contribution Works basis.</i></p> <p><i>(g) Application for change of tariff.</i></p> <p><i>(h) Application for repair or replacement of Board's properties damaged due to dashing of vehicles etc., by the third parties chargeable under Deposit Contribution Works basis.</i></p>
<p>5.(a)</p>	<p><b>7. Installation of Meter</b></p> <p>(1) Sub-section (1) of section 55 of the Act provides for the use of meters and reads as “No Licensee shall supply electricity, after the expiry of two years from the appointed date, except through installation of a correct meter in accordance with the regulations to be made in this behalf by the Authority:</p> <p>Provided that the Licensee may require the consumer to give him security for the price of a meter and enter into an agreement for the hire thereof, unless the consumer elects to purchase a meter:</p> <p>Provided further that the State Commission may, by notification, extend the said period of two years for a class or classes of persons or for such area as may be specified in the notification.”</p> <p>(2) All new service connections shall be extended with meters only. For all new LT service connections, the Licensee shall install meters with demand recording facility.</p>	<p><b>7. Installation of Meter</b></p> <p><i>(1) No new service connection shall be given without meter. For all new LT service connections, the Licensee shall install meters with demand recording facility.</i></p> <p><i>(2) At the time of seeking a new connection / temporary service connection, the applicant shall have the option either to purchase a meter on his own as per prescribed standards, specifications and relevant Regulations or require that meter to be supplied by the</i></p>

		<p><i>Distribution Licensee. Unless the consumer elects to purchase his own meter, the Licensee shall provide meters complying statutory standards and relevant Regulations and may require the consumer to give adequate security for the price of the meter and pay the hire charges there for. Where the consumer elects to purchase his own meter, the Licensee shall ensure that such meter complies with relevant standards, specifications and Regulation. Meters purchased by the consumer shall be tested, installed and sealed by the Licensee. A tracking and recording software for all new seals shall be provided by the manufacturer of the meter so as to track total movement of seals starting from manufacturing, procurement, storage, record keeping, installation, series of inspections, removal and disposal. Only the patented seals (seal form the manufacturer who has official right to manufacture the seal) shall be used. The consumer shall claim the meter purchased by him as his asset only after it is permanently removed from the system of the Licensee.</i></p> <p><i>The Licensee shall publish and keep on updating on their web-portal about type, single phase / three phase capacity rating with respect to demand applied, specification along with the list of approved meter manufacturers and information of the places from where the consumers can purchase those meters. It shall cover all categories of LT, LT CT, HT , Bidirectional metering, solar generation, pre paid metering, ToD metering etc., on a permanent basis without any restriction in terms of period of duration for purchase, quantity of meters to be purchased by a division / circle etc.,</i></p>
--	--	---



<p>5c.</p>	<p>(3) Unless the consumer elects to purchase his own meter, the Licensee shall provide meter of high quality, high precision and accuracy and may require the consumer to give adequate security for the price of the meter and pay the hire charges therefor. Where the consumer elects to purchase his own meter, the Licensee shall ensure that such meter is of high quality, high precision and accuracy and shall arrange to recalibrate the same at consumer cost.</p> <p>(3A) In case of open access consumer, ABT compliant meter with facilities to record export and import of energy shall be provided both at the generator and consumer ends in accordance with the Central Electricity Authority (Installation and Operation of Meters) Regulations, 2006.</p> <p>(4) xxx (5) xxx (6) xxx</p> <p>(7) All HT services shall be provided with HT metering. Wherever existing metering of the High Tension Service connection is on the Low Tension side i.e. on the secondary side of the Transformer:</p>	<p><i>(3) The Licensee shall endeavor to provide smart pre-payment meter or pre-payment meter in a phased manner giving priority to services of higher consumption/revenue. All Central/State Govt. and local body services shall be provided with smart meters with facility of pre-payment mode. In areas which do not have communication network, pre payment meters shall be provided. For temporary supply, pre-payment meters (Rechargeable card Model) shall be provided. For pre-payment meter, payment of security deposit is not required.</i></p> <p><i>(3A) In case of open access consumer, the Interface meters with facilities to record export and import of energy and other parameters depending upon tariff requirement shall be provided both at the generator and consumer ends and other required locations. The meters shall comply with relevant standards and specifications in accordance with the Central Electricity Authority (Installation and Operation of Meters) Regulations, 2006, as amended from time to time.</i></p> <p><i>(4) xxx (5) xxx (6) xxx</i></p> <p><i>(7) All HT services shall be provided with HT metering. Wherever existing metering of the High Tension Service connection is on the Low Tension side i.e. on the secondary side of the Transformer:</i></p>
------------	--	--

<p>5c.</p>	<p>(i) The average losses in the transformer shall be calculated as follows and added to the energy consumption indicated by the meter :—</p> $\text{Average loss} = \frac{720 \times 1.0 \times C}{100} \text{Units per month}$ <p>Where C=KVA rating of the transformer</p> <p>(ii) The transformer loss arrived at by the above formula shall be added to the energy consumption, even when the recorded energy consumption is nil.</p> <p>(iii) xxx</p> <p>(8) xxx</p> <p>(9) If the consumer considers that the meter is defective, he may apply to the</p>	<p><i>(i) The average losses in the transformer shall be calculated as follows and added to the energy consumption indicated by the meter :—</i></p> $\text{Average loss} = \frac{720 \times 1.0 \times C}{100} \text{Units per month}$ <p><i>Where C=kVA rating of the transformer.</i></p> <p><i>(ii) when the above formula is made applicable for the LT services of more than 112kW in accordance with sub-regulation 3(1)(b) of this Code or the capacity of the feeding transformer is more than capacity required to feed the contracted demand of the individual consumer, the kVA rating of the transformer represented as C in the above formula shall be limited to the lower capacity of the transformer of available rating being used by the Licensee which is actually required to meet the quantum of contract demand of the individual consumer.</i></p> <p><i>The transformer loss arrived as above, shall be added to the energy consumption, even when the recorded energy consumption is nil.”</i></p> <p>(iii) xxx</p> <p>(8) xxx</p> <p>(9) If a consumer considers that the meter is defective or meter readings not being</p>
------------	--	---

Licensee to have a special test carried out on the meters at any time and the cost of such a test shall be borne by the Licensee or the consumer according as the meter is found defective or correct as a result of such a test. <sup>1</sup>[The aforementioned special test for the disputed energy meters including the suspected/defective meters shall be carried out in the Third Party testing laboratory accredited by National Accreditation Board for Testing and Calibration Laboratories (NABL) and till such time the Third Party Meter Testing Arrangement is established, the licensee shall have the special test conducted by the Chief Electrical Inspector to Government of Tamil Nadu]. The meter shall be deemed to be correct if the limits of error do not exceed those laid down in the relevant rules made under the Act. The consumer may also be allowed to install a check meter after recalibration by the Licensee. Such check meter shall be of high quality, high precision and high accuracy and sealed by the Licensee. Whenever the Licensee's meter becomes defective the check meter reading may be taken for billing.

*commensurate with his consumption of electricity, he may apply to the Licensee to have a special test carried out at Licensees' lab. The test shall be carried out by Licensee within 30 days and the cost of such a test shall be borne by the Licensee or the consumer according to the result of such test as to whether the meter is defective or correct.*

*The distribution licensee shall convey the date and time for such test to the consumer for his presence during testing. After testing, the Licensee shall give a copy of test report to the consumer duly signed by both the Licensee and the consumer, and retain one copy as acknowledgment. However, if the consumer opts not to be present at the site for testing, the distribution licensee shall carry out such testing and send copy of the report to the consumer, If the consumer disputes the results of such testing and demands re-testing by third party by accepting to bear the charges for such test the Licensee shall arrange the testing at third party testing Lab accredited by NABL from the list of third party testing agencies approved by the Commission. If it is established that the errors are beyond the specified limits and contrary to the results of the test performed by the Distribution Licensee, the cost of carrying out such test already paid by the consumer shall be reimbursed by the Distribution Licensee. However in case it is established that the results of the test are the same as the results of the test performed by the Distribution Licensee, the cost of carrying out such test shall stand to be borne by the consumer. The meter data and test results shall be issued to the consumer and said results are final and binding on both the consumer and distribution*

5d.	<p>(10) The procedure to be followed for replacement of defective/ damaged/ burnt meter shall be as follows:</p> <p>(i) It is the responsibility of the Licensee to replace all defective meters belonging to the licensee at his cost.</p> <p>(ii) Since the safe custody of the meter is the consumer's responsibility, replacement of meter due to damages shall be at the cost of consumer.</p> <p>(iii) The cost of replacement for burnt meters shall be met by the Licensee unless it is proved otherwise that the burning out is due to the fault of the consumer.</p>	<p>licensee.</p> <p><i>The list of third party agencies approved by the Commission shall be available in various offices and the website of the distribution licensee.</i></p> <p>(10) <i>The procedure to be followed for replacement of defective/ damaged/ burnt/ meter shall be as follows:</i></p> <p><i>(i) It is the responsibility of the Licensee to replace all defective meters belonging to the Licensee at his cost. The meter with defects such as stoppage of recording, stoppage of display, damage to seal, burning or damage to meter etc either on consumers complaint or upon inspection by the Distribution Licensee shall be replaced within the duration as specified by the Commission and restore supply through a new meter. The released defective meter shall be tested within 30 days in licensee's lab. Wherever feasible, the data shall be downloaded. The records of all defective meters shall be accompanied with allied documentation of such test results. The important data downloaded such as meter reading and other data relevant to billing shall be documented in the consumer ledger. No defective meter shall be handed over to stores without testing in licensee's lab.</i></p> <p><i>(ii) Since the safe custody of the meter is the consumer's responsibility, replacement of meter due to damages shall be at the cost of consumer.</i></p> <p><i>(iii) If after investigation, it is found that the meter has become defective or burnt due to reasons attributable to the consumer, the cost of new meter and other applicable charges shall be recovered from the consumer through</i></p>
-----	--	--

<p>5e.</p>	<p>(iv) When the meter is owned by the consumer and becomes defective / damaged or when the meter is burnt due to the fault of the consumer, it is the responsibility of the consumer to replace the meter by a healthy one, if he elects to continue to have his own meter. Otherwise the Licensee shall replace the meter and enter into an agreement for hire and collect the specified deposits.</p>	<p><i>subsequent bills. No fee shall be charged from the consumer at the time of reporting by consumer or being noticed by licensee that the meter is defective or burnt.</i></p> <p><i>Besides the said charges for replacement of defective/ burnt meter, necessary bill revision for the period of defect or inaccurate recording of consumption , shall be made as per provisions of this Code and the excess or deficit charges shall be adjusted in the subsequent bills with due intimation to the consumer in writing along with test results and working sheet.</i></p> <p><i>Sufficient rolling stock of meter shall be maintained in every section offices of the Licensee for timely replacement of defective meters.</i></p> <p><i>(iv) When the meter is owned by the consumer and becomes defective / damaged or burnt due to the fault of the consumer, it is the responsibility of the consumer to replace the meter by a healthy one, if he elects to continue to have his own meter. Otherwise the Licensee shall replace the meter, collect the specified deposits/ applicable Charges from the consumer.</i></p> <p><i>(11) In case of single phase meters, the consumer shall ensure there is no common neutral or phase or looping of neutral or phase of two or more consumers on consumer side wiring. If such common neutral or phase or looping of neutral or phase comes to the notice of the Licensee or if the earth leakage indication is displayed in the meter, the Licensee shall inform the consumer in writing</i></p>
------------	--	--

		<i>advising him to rectify the defect to ensure proper recording of consumption.</i>
6a.	<p><b>8.Meter Reading, Billing and intervals</b></p> <p>(1) xxx  (2) xxx  (3) (blank)</p>	<p><b>8. Meter Reading, Billing and intervals</b></p> <p>(1) xxx  (2) xxx  (3) <i>The meter shall be read at least once in every billing cycle in urban as well as rural areas by an authorized representative of the distribution licensee. Services of all status such as existing services, newly released services during previous billing cycle, service remaining under disconnection etc., shall be covered in the regular assessment of such periodicity. In case of smart meters, the meters shall be read remotely at least once in every billing cycle and in case of other pre-payment meters; the meters shall be read by an authorized representative of the distribution licensee at least once in every three months. The data regarding remote assessment and billing shall be made available to the consumer, through website or mobile App or SMS, etc. Consumers having smart pre-payment meters may also be given the data access for checking their consumption.</i></p>
6b.	<p>4) “In case of LT services the meter readings of last digit up to and inclusive of five units shall be rounded off to the lower multiple of ten units and the meter readings of last digit from six to nine units shall be rounded off to the higher multiple of ten units.”</p>	<p>(4) <i>Omitted.</i></p>
6c.	<p>5) In case of LT services, after taking the meter readings, the particulars of meter readings, energy consumption and charges payable will be incorporated in the consumer meter card.</p>	<p>(5) <i>In case of LT services, after taking the meter readings, the particulars of meter readings, energy consumption and charges payable shall be incorporated in the consumer meter card.</i></p>

<p>6d.</p>	<p>6) Payment for energy supplied shall be made by the consumer according to the meter readings referred to above and on delivery of a bill therefor in the case of High Tension consumers and incorporation of current consumption charges in the consumer meter card or assessment slip in the case of Low Tension consumers.</p>	<p><i>Wherever the particulars of meter readings, energy consumption, charges payable and last date for payment etc., are sent to the consumer through SMS and Mail to the registered mobile number and e-mail id respectively, such communication shall also be construed as Bill-cum-Notice in relation to the provisions contained under Regulations 8, 13 and 14 of this Code.</i></p> <p><i>(6) Procedure of generation and issue of billing:</i></p> <p><i>(a) Payment for energy supplied shall be made by the consumer according to the meter readings referred to above and on delivery of a bill therefor in the case of High Tension consumers and incorporation of current consumption charges in the consumer meter card or assessment slip in the case of Low Tension consumers. In case of pre-payment metering, the distribution licensee shall issue the bill, to the consumer, on his request.</i></p> <p><i>Pre-payment meters shall be designed to automatically cut off supply when the amount credited is exhausted. This shall however not be treated as a disconnection and the supply will be resumed whenever the meter is recharged.</i></p> <p><i>(b) The distribution licensee shall intimate the consumer about despatch of bill through SMS, immediately after the despatch in case of HT services and within a period of not more than four working days from the date of the assessment in case of LT services. The intimation shall consist of the details of bill amount and the due date for payment.</i></p> <p><i>The distribution licensee shall also upload the</i></p>
------------	---	---

		<p><i>bill on its website on the day of bill generation. The billing and payment details of minimum last one year for all consumers shall be made available on the licensee's website.</i></p> <p><i>(c) The distribution licensee shall issue the first bill in the same billing month for HT, LT CT services and temporary services. For other services the first bill shall be issued preferably in the same billing month but not exceeding two billing months from the date of effecting a new connection where post payment meters are installed.</i></p> <p><i>(d) In case the consumer does not receive the first bill within such period or any regular bill in subsequent periods, he shall complain in writing to the distribution licensee and the distribution licensee shall issue the bill within seven days. The consumer can also get his billing details from Licensee's website.</i></p> <p><i>(e) The consumer is equally responsible to make the payment promptly and regularly for the electricity consumed by him from the Licensee.</i></p> <p><i>(f) The distribution licensee shall not generate more than two provisional bills for a consumer during one financial year and if the provisional billing continues for more than two billing cycles except under extraordinary situation due to force majeure, the consumer may refuse to pay the dues until bill is raised by the distribution licensee as per actual meter reading.</i></p> <p><i>(g) The information regarding the authority with whom grievance or complaint pertaining to bill can be lodged shall be provided along with the bill and the same shall also be made available</i></p>
--	--	---



		<p><i>on distribution Licensee's website.</i></p> <p><i>(h) In case of vacation of premises, the distribution licensee shall arrange to take a special reading of the meter on receiving the consumer's written request and issue a final bill including all arrears till the date of billing and issue a No-Dues Certificate on receiving final payment, within seven days from the receipt of such payment.</i></p>
7.	<p><b>9. Meter readings when there is changes in sanctioned demand etc.,</b></p> <p>(1) Whenever there is change in the sanctioned demand, the change shall be effected, as far as possible, to coincide with the next meter reading. If, however, it is not possible so to do, the meter shall be reset and the maximum demand charges shall be billed proportionately for the respective periods.</p>	<p><b>9. Meter readings when there is changes in sanctioned demand etc.,</b></p> <p>(1) xxx</p> <p><i>Revised Test Report (RTR) shall be taken incorporating all relevant details of change in demand except temporary reduction of demand. The date of RTR shall be the date of effect of change in demand. The changes made in respect to meter/metering system such as meter details /CT details / C.T. ratio available / adopted, change in M.F meter/meter box seals etc shall be documented in the RTR clearly. However, for temporary reduction of demand effected on seasonal basis as requested by the consumer without any change in the metering system, the RTR is not necessary.</i></p> <p><i>(1A) Dynamic reduction of load to suit the seasonal requirement is applicable to Industries other than IT services covered under IIIB and marriage halls covered under</i></p>

	<p>(2) xxx</p>	<p><i>Tariff V. Dynamic reduction of demand shall be effected on application by the consumer. Such application shall be made online in a simple format. No other charges than registration fee is payable. No inspection is necessary. The metering system need not be de-rated for temporary load reduction The reduction in demand shall take effect the date of meter reading and MD reset of succeeding assessment following the date of application. Contracted demand shall continue to be unaltered in their Test report and contracted agreement. After the requested period for temporary reduction demand is over, the level of demand shall be resumed automatically to the original contracted demand.</i></p> <p><i>The reduction of demand shall be applicable for a minimum of one billing cycle. Reduction of demand is permissible two times in a financial year irrespective of the duration for which reduction of demand is required.</i></p> <p><i>In case the level of temporarily reduced demand is exceeded in a billing cycle, the fixed charges for the entire billing cycle shall be payable to the original contracted demand only and not proportionately. Licensee shall enable the application and billing software for seamless processing.</i></p> <p>(2) xxx</p>
<p>8.</p>	<p><b>10. Inaccessibility of meter for reading.</b></p> <p>(1) To (5) xxx</p>	<p><b>10. Inaccessibility of meter for reading.</b></p> <p>(1) To (5) xxx</p> <p>(6) <i>In case of unforeseen constraints on the part of Licensee to carry out the assessment /</i></p>

		<p><i>force-majeure conditions, the Licensee may have the option of allowing the consumer to send the picture of meter display of the respective service connection that indicates the meter reading of billing parameters and the date of such readings, through registered mobile or e-mail to the designated officer of the Licensee.</i></p>
9a.	<p><b>11. Assessment of billing in cases where there is no meter or meter is defective:</b></p> <p>(1) Where supply to the consumer is given without a meter or where the meter fixed is found defective or to have ceased to function and no theft of energy or violation is suspected, the quantity of electricity supplied during the period when the meter was not installed or the meter installed was defective, shall be assessed as mentioned hereunder.</p> <p>(2) xxx (3) xxx (4) xxx (5) xxx (6) xxx</p>	<p><b>11. Assessment of billing in cases where the meter is defective:</b></p> <p><i>(1) Where the meter fixed is found defective or burnt or to have ceased to function and no theft of energy or violation is suspected, the quantity of electricity supplied during the period when the meter was defective, shall be assessed based on the data downloaded through CMRI from the defective meter and scrutiny of those data , load curve etc., besides taking into consideration of site condition to corroborate the assessment so made. Wherever such downloading of data could not be done, the reason for not getting the meter tested or the reason for not downloading the data from the defective or burnt meter shall be recorded and signed by the designated authority by the Licensee. Wherever the data could not be downloaded, the quantity of electricity supplied during the period when the meter was defective, shall be assessed as mentioned hereunder.”</i></p> <p>(2) xxx (3) xxx (4) xxx (5) xxx (6) xxx</p>

9b.	(7) xxx	<p><i>In all above cases, the relevant test results and clear working sheet indicating the basis of computation of billing for the back period, the period during which the meter was found defective etc., shall be promptly communicated to the consumer in writing under acknowledgement.</i></p> <p>(7) xxx</p>
10.	<p><b>14A Notice to consumers under automated meter reading system-</b> Notwithstanding anything contained in regulations 5,8,13,14 and 16 of this code or any provision in the Distribution Code, wherever the Licensee implements automated meter reading system through Automated Meter Reading (AMR) Technology/ Advanced Metering Infrastructure (AMI) Technology using smart meters/ any other modern technology using smart meter, the billing details such as, Electricity Consumption, Consumption charges for electricity, the due date of payment, demand for additional Security Deposit, any other demand/information etc., shall be communicated through e-mail or SMS or Mobile App or any other electronic mode adopted by the TANGEDCO with prior intimation to the Commission and such communication shall be deemed to be the notice issued for such purposes.</p>	<p><b>“14A Notice to consumers under automated meter reading system-</b> <i>Notwithstanding anything contained in regulations 5,8,13,14 and 16 of this code or any provision in the Distribution Code, wherever the Licensee implements automated meter reading system through Automated Meter Reading (AMR) Technology/ Advanced Metering Infrastructure (AMI) Technology using smart meters/ any other modern technology using smart meter or computerized billing, the billing details such as, Electricity Consumption, Consumption charges for electricity, the due date of payment, demand for additional Security Deposit, any other demand/information etc., shall be communicated through e-mail or SMS to the registered mobile number/e-mail id or any other electronic mode adopted by the Licensee with prior intimation to the Commission and such communication shall be deemed to be the notice issued for such purposes.</i></p> <p><i>For this purpose, all consumers have to register their mobile number/ e-mail id with the Licensee and it is the responsibility of the consumer to ensure the correctness and periodical updation of mobile number and e-mail id, so registered. However, the Licensee has to provide appropriate facility for such verification and updation.</i></p>

11a.	<b>15.Mode of Payment</b> <p>(1) The licensee shall issue receipts for every recovery or payment from the consumers.</p>	<b>15.Mode of Payment</b> <p><i>(1) The licensee shall issue receipts for every recovery or payment from the consumers. Consumer shall have option to pay bills online or offline.</i></p>
11b.	<p>(2) All High Tension bills, including those on account of miscellaneous charges, shall be paid within the due date fixed by the Licensee from the date of the bill. The High Tension Consumer shall pay the bills in cash or by demand draft on local bank or Cheque drawn on a bank at the headquarters of the designated authority of the distribution licensee or through electronic payment or collection through bank's branch counters or post office as stipulated by the distribution licensee. Payment for amounts exceeding Rs.2000/- (Rupees two thousand only) is preferred by DD/ Cheque. Depending on the circumstances, the designated authority of the distribution licensee shall however accept cash payments also and advise the consumer for future remittances by DD / Cheque. In case the Cheque is dishonored for any reason whatsoever, the High Tension consumer will be required to pay the High Tension bills in cash or by demand draft thereafter. If the payment is not received within fifteen days (notice period) from the expiry of the due date allowed for payment, the supply will be disconnected. However the consumer may be allowed extension of time to make payment beyond the expiry of the notice period allowed for payment, on an application made to the designated authority of the Distribution Licensee, subject to the levy</p>	<p><i>(2) All High Tension bills, including those on account of miscellaneous charges, shall be paid within the due date fixed by the Licensee from the date of the bill. The High Tension Consumer shall pay the bills through electronic mode such as RTGS/NEFT/Online money transfer for all payments of more than Rs.1000. Depending on the circumstances, the designated authority of the distribution licensee shall however accept cash payments on special occasions and unavoidable circumstances. If the payment is not received within fifteen days (notice period) from the expiry of the due date allowed for payment, the supply will be disconnected. However the consumer may be allowed extension of time to make payment beyond the expiry of the notice period allowed for payment, on an application made to the designated authority of the Distribution Licensee, subject to the levy of BPSC as specified in this Code.</i></p>

	<p>of BPSC as specified in this Code.</p> <p>(3) Low Tension Consumers shall pay the amount due in cash or by money order or by demand draft on local bank, or by Cheque drawn on a bank where the Distribution Section Office is located or through electronic payment or collection through bank's branch counters or post office, etc. as stipulated by the distribution licensee. However, local bodies and Railways may issue Cheque on the banks situated in the place of their office and the Licensee may claim the collection charges, if any, from such consumers. Payment for amounts exceeding Rs.5000/-(Rupees five thousand only) is preferred by DD / Cheque. Depending on the circumstances, the designated authority of the distribution licensee shall however accept cash payments also and advise the consumer for future remittances by DD / Cheque.</p> <p>(4) xxx</p>	<p><i>(3) Low Tension Consumers shall pay the amount due in cash or online or by money order or by demand draft on local bank, or by Cheque drawn on a bank where the Distribution Section Office is located or through electronic payment or collection through bank's branch counters or post office, etc. as stipulated by the distribution licensee. However, local bodies and Railways may issue Cheque on the banks situated in the place of their office and the Licensee may claim the collection charges, if any, from such consumers. Payment for amounts exceeding Rs.1000/- (Rupees one thousand only) is preferred by DD / Cheque/ online payment. Depending on the circumstances, the designated authority of the distribution licensee shall however accept cash payments also and advise the consumer for future remittances by DD / Cheque/online payment.</i></p> <p>(4) xxx</p>
<p>12a.</p>	<p><b>17. Agreement with respect to Supply: Issues on recovery of charges</b></p> <p>(1) to (6) xxx</p> <p>(7) The licensee shall on receipt of the notice referred to in sub-regulation (3) make such adjustment of the dues due to him from the consumer as may be necessary to clear the dues from the consumer against the security deposit or additional security deposit or any other deposit made by the consumer, and</p>	<p><b>17. Agreement with respect to Supply: Issues on recovery of charges</b></p> <p>(1) to (6) xxx</p> <p><i>(7) The licensee shall on receipt of the notice referred to in sub-regulation (3) make such adjustment of the dues due to him from the consumer as may be necessary to clear the dues from the consumer against the security deposit or additional security deposit or any other deposit made by the consumer, and after making such adjustment, refund the</i></p>

<p>12b.</p>	<p>after making such adjustment, refund the balance deposit, if any, to the consumer within three months from the date of expiry of the notice period referred to in sub – regulation (3).</p> <p><i>(8)Where any consumer has more than one service connection, if he defaults in the payment of dues relating to any one of the service connections, the licensee may cause other service connections in the name of the consumer to be disconnected on issuing proper notice till all the arrears due for all the service connections are paid, notwithstanding the fact that the service connections are covered under separate agreements.”</i></p> <p>9(a) to 9(c) xxx</p>	<p><i>balance deposit, if any, to the consumer within three months from the date of expiry of the notice period referred to in sub-regulation (3) by direct credit to the account of consumer under advice to him, if bank account details are provided.</i></p> <p><i>(8)Where any consumer has more than one service connection, if he defaults in the payment of dues relating to any one of the service connections that includes dues pointed out by validated audit, charges due to theft of energy, violation, dues relating to deposit contribution works, etc., the licensee may include such dues in other service connection(s) in the name of the consumer and cause those service connection(s) to be disconnected after issuing proper notice with working sheet and quoting the authority under which such dues are payable, till all the arrears due for all the service connections are paid, notwithstanding the fact that the service connections are covered under separate agreements.</i></p> <p>9(a) to 9(c) xxx</p>
<p>13.</p>	<p><b>19. Unauthorized use of Electricity – Investigation and Enforcement Provisions</b></p> <p>(1) xxx  (2) xxx  (3) xxx  (4) xxx  (5) xxx  (6) The assessment under this section shall be made at a rate equal to twice the tariff applicable for the relevant category</p>	<p><b>19. Unauthorized use of Electricity – Investigation and Enforcement Provisions</b></p> <p>(1) xxx  (2) xxx  (3) xxx  (4) xxx  (5) xxx  (6)The assessment under this section shall be made at a rate equal to twice the tariff applicable for the relevant category for which</p>

	<p>of services specified in sub-section (5).</p> <p>Explanation: xxx</p>	<p><i>the load was found to have been misused for the period specified in sub-section (5) excluding the cost of supplied electricity already paid by the consumer for the units/demand recorded in the meter for the period for which such assessment is made. The formula for the assessment is given in Form 8-A in Appendix to this Code.</i></p> <p><i>Explanation: xxx</i></p>
<p>14(a)</p>	<p><b>22. Restoration of supply of electricity</b>                  (1) The Licensee shall restore the supply to the service immediately and in any case not exceeding twelve hours in the case of urban areas and twenty four hours in the case of rural areas on recovery of electricity charges or such other sums together with any expenses incurred by the Licensees in cutting off and re-connecting the supply.</p> <p>(2) to (5) xxx</p>	<p><b>22. Restoration of supply of electricity</b>  <i>(1) The Licensee shall restore the supply to the service immediately and in any case not exceeding six working hours on receipt of electricity charges or such other dues and other charges as applicable.</i></p> <p>(2) to (5) xxx</p>
<p>14b.</p>	<p>(6) (i) xxx</p> <p>(ii) The authorized Officer of the Licensee may permit such consumer to pay the outstanding in installments and to avail reconnection on receipt of 40% of the total arrears outstanding after closing of account due to the licensee, which include –</p> <p>(a) Arrears on the date of disconnection.                  (b) Tariff minimum and meter rent for the period of six months from the date of disconnection (including the notice</p>	<p>(6) (i) xxx</p> <p>(ii) <i>The authorized Officer of the Licensee may permit such consumer to pay the outstanding in installments and to avail reconnection on receipt of 40% of the total arrears outstanding after closing of account due to the licensee, which include –</i></p> <p><i>(a) Arrears on the date of closure of accounts.                  (b) The applicable BPSC / interest upto the date of payment.</i></p>



	<p>period)</p> <p>(c) The applicable BPSC / interest upto the date of payment.</p> <p>(d) The balance 60% of the amount shall be collected in ten monthly installments.</p> <p>(e) In addition to the above, the full amount of Security Deposit adjusted while closing of account shall be collected in one lumpsum before effecting new service connection.”</p> <p>Explanation: For the purpose of removal of doubts, it is hereby declared that any tariff minimum collected by the Tamil Nadu Electricity Board prior to the date of publication of the Tamil Nadu Electricity Supply (Amendment) Code, 2006 in the <i>Tamil Nadu Government Gazette</i>, that is to say prior to 21st June 2006 on the basis of sub-regulation (6) as it stood before the said amendment need not be refunded by the Tamil Nadu Electricity Board.</p>	<p>(c) <i>The balance 60% of the amount shall be collected in ten monthly installments. In addition to the above, the full amount of Security Deposit adjusted while closing of account shall be collected in one lumpsum along with the aforesaid portion of 40% before effecting restoration of supply.</i></p> <p><i>Explanation: For the purpose of removal of doubts, it is hereby declared that any tariff minimum collected by the Tamil Nadu Electricity Board prior to the date of publication of the Tamil Nadu Electricity Supply (Amendment) Code, 2006 in the Tamil Nadu Government Gazette, that is to say prior to 21st June 2006 on the basis of sub-regulation (6) as it stood before the said amendment need not be refunded by the Tamil Nadu Electricity Board.</i></p>
<p>15.</p>	<p><b>23(AA) The Procedure for assessment of the electricity charges, disconnection of supply of electricity and removing the meter, electric line, electric plant and other apparatus in case of theft of electricity as detailed in section 135 of the Act is given below:</b></p> <p>(1) xxx</p> <p>(2) xxx</p> <p>(3) xxx</p> <p>(4) xxx</p> <p>(5) xxx</p> <p>(6) Xxx</p>	<p><b>23(AA) <i>The Procedure for assessment of the electricity charges, disconnection of supply of electricity and removing the meter, electric line, electric plant and other apparatus in case of theft of electricity as detailed in section 135 of the Act is given below:</i></b></p> <p>(1) xxx</p> <p>(2) xxx</p> <p>(3) xxx</p> <p>(4) xxx</p> <p>(5) xxx</p> <p>(6) Xxx</p>

<p>(7) Where it is established that there is a case of theft of energy, the authorized officer shall assess the quantum of energy consumption for the past twelve months as per the assessment formula given in Form 8 in Appendix to this code and prepare provisional assessment order for the charges for such consumption at two times of the tariff applicable (i.e., the applicable tariff for the purpose for which the pilfered energy was used) and serve on the accused person under proper receipt. The authorized officer may reduce the period for such billing if it is established by the facts or documents submitted in the representation of the accused person or any such other evidence observed by the authorized officer. Wherever electronic meters are installed and the load curves are studied periodically, the period of theft could be limited to the exact period as could be determined scientifically. The authorized officer shall record reasons for such reduction in the period of billing, in the assessment order. The energy consumption arrived at as per the formula referred to in the said Form 8 will be charged excluding the energy consumption recorded by the meter as per the rates specified by the Commission's Tariff Order.</p> <p>Provided that if the quantum of energy consumption is recorded in the meter installed by the Distribution Licensee in the consumer's premises, the authorized</p>	<p><i>(7) Where it is established that there is a case of theft of energy, the authorized officer shall assess the quantum of energy consumption for the past twelve months as per the assessment formula given in Form 8 in Appendix to this code and prepare provisional assessment order for the charges for such consumption at two times of the tariff applicable (i.e the applicable tariff for the purpose for which the pilfered energy was used) and serve on the accused person under proper receipt. The authorized officer may reduce the period for such billing if it is established by the facts or documents submitted in the representation of the accused person or any such other evidence observed by the authorized officer. Wherever electronic meters are installed and the load curves are studied periodically, the period of theft could be limited to the exact period as could be determined scientifically. The authorized officer shall record reasons for such reduction in the period of billing, in the assessment order. The energy consumption arrived at as per the formula referred to in the said Form 8 will be charged excluding the energy consumption recorded by the meter as per the rates specified by the Commission's Tariff Order.</i></p> <p><i>Provided that Section 135 shall be invoked only for the following cases involving the offence of theft of energy:</i></p> <p><i>(i) cases where the energy is not recorded/</i></p>
--	--

	<p>officer shall arrive such energy consumption as per the assessment formula given in Form 8-A in Appendix to this Code.</p> <p>(8) to (22) xxx</p>	<p><i>partially recorded in the meter.</i></p> <p><i>(ii) cases of illegal restoration of disconnected services.</i></p> <p>(8) to (22) xxx</p>
<p>16a.</p>	<p style="text-align: center;"><u>Form 8</u></p> <p style="text-align: center;"><u>[See Regulation 23 (AA) (7)]</u></p> <p style="text-align: center;">FORMULA TO ASSESS THE QUANTUM OF ENERGY IN CASE OF THEFT OF ELECTRICITY</p> <p>I.(A) to (D) xxx</p> <p><b>(E) i.</b> xxx.</p> <p>ii (a) For High Tension Service connections, the maximum demand shall be assessed as 75% of the total connected load at the time of inspection subject to a minimum of the contracted demand. A power factor of 0.90 lag may be used for conversion of KVA or KW.</p> <p>(b) Assessment of demand charges:-</p> <p style="padding-left: 40px;">Twice the appropriate H.T. tariff rate for maximum demand.</p>	<p style="text-align: center;"><u>FORM 8</u></p> <p style="text-align: center;"><u>[Refer Regulation 23 (AA) (7)]</u></p> <p style="text-align: center;">FORMULA TO ASSESS THE QUANTUM OF ENERGY IN CASE OF THEFT OF ELECTRICITY</p> <p>I.(A) to (D) xxx</p> <p><b>(E) i.</b> xxx.</p> <p><b>ii Assessment of quantum of demand charges in HT service and fixed charges in LT services:</b></p> <p><i>(a) For all Service connections, the maximum demand shall be assessed as 75% of the total connected load at the time of inspection subject to a minimum of the sanctioned / contracted demand. A power factor of 0.90 lag for HT and 0.85 lag for LT shall be used for conversion between kVA and kW.</i></p> <p><i>(b) Assessment of demand charges for HT services:-</i></p> <p style="padding-left: 40px;"><i>Twice the appropriate H.T. tariff rate for maximum demand.</i></p> <p><i>(c) Assessment of fixed charges for LT services:-</i></p> <p style="padding-left: 40px;"><i>Twice the appropriate LT tariff rate for</i></p>

<p>16b.</p>	<p><b>II. Assessment of quantum of energy consumption in a case of illegal restoration of supply to a disconnected service connection shall be as follows:</b></p> <p>(A) The period of assessment will be for twelve months immediately preceding the date of detection of the violation or for the period from the date of disconnection of the service connection to the date of detection of the illegal restoration, whichever period is less:</p> <p>(B) The quantum of energy consumed for assessment of charges for theft of electricity in accordance to sub-regulation 7 of regulation 23AA shall be as follows:</p> <p>(i) When the meter is healthy:- Units recorded from the date of disconnection of the service connection to the date of detection.</p> <p>(ii) When the meter is found defective:- Quantum of energy computed (U) using the formula above.</p> <p>(C) The assessment shall be at two times the applicable energy charges and two times the applicable demand charges where applicable.</p>	<p><i>fixed charges.”</i></p> <p><b><i>II. Assessment of quantum of energy consumption and charges in case of illegal restoration of supply to a disconnected service connection shall be as follows:</i></b></p> <p><i>(A) The period of assessment will be for twelve months immediately preceding the date of detection of the illegal restoration of supply or for the period from the date of disconnection of the service connection to the date of detection of the illegal restoration, whichever period is less:</i></p> <p><i>(B) The quantum of energy for assessment and computation of assessment charges for illegal restoration of supply shall be as follows:</i></p> <p><i>(i) When the meter is healthy: - Units recorded from the date of disconnection of the service connection to the date of detection. The assessment shall be equal to twice the tariff applicable that includes both the energy and demand/fixed charges. The tariff charges for the units/demand recorded in the meter for the period for which the assessment is made shall not be collected. If collected, the same shall be credited to the consumer account.</i></p> <p><i>(ii) When the meter is found defective: - Quantum of energy consumed by illegal restoration of energy (U) shall be computed using the formula above given in part I.</i></p> <p><i>(C) The assessment shall be at two times the applicable charges of electricity that includes both energy charges and demand/fixed charges.</i></p>
-------------	---	---

		<p><i>(D) In addition to the above assessment charges, all other procedures laid down under sub-regulation 23 (AA) of this Code including the stipulations in regard to compounding the offence shall be followed.“</i></p> <p><i>Note: The applicable tariff as specified for assessment is the tariff in force during such period of assessment for all the above cases dealt under FORM 8.</i></p>
<p>17a.</p>	<p style="text-align: center;"><b>Form 8-A</b></p> <p>[(See proviso of clause 23 (AA)( 7)]  <b>FORMULA TO ASSESS THE QUANTUM OF MISUSED ENERGY IN THE CASE WHOEVER DISHONESTLY USES ELECTRICITY FOR THE PURPOSE OTHER THAN FOR WHICH THE USAGE OF ELECTRICITY WAS AUTHORIZED AS REFERRED IN SECTION 135 (1)(e) OF THE ELECTRICITY ACT 2003</b></p> <p>(i) xxx  (ii) xxx  (iii)(a) to (iii)(f) xxx</p>	<p style="text-align: center;"><b>FORM 8-A</b></p> <p>[Refer Regulation 19 (6)]  <b>FORMULA TO ASSESS CHARGES TOWARDS UNAUTHORIZED USE OF ELECTRICITY UNDER SECTION 126 OF THE ELECTRICITY ACT 2003.”</b></p> <p>(i) xxx  (ii) xxx  (iii)(a) to (iii)(f) xxx</p> <p><b>Note:</b> <i>The tariff for unauthorized use (d) as specified in the above formulae for assessing the charges is the tariff in force during such period of assessment</i></p>
<p>17b.</p>		
<p>18.</p>	<p style="text-align: center;"><b>Form 9</b></p> <p>[ See Regulation 23 (AA) (8)]  <b>Provisional Assessment order for *theft of energy under section 135/138 of the Electricity Act, 2003.</b></p> <p>From (The Authorised Officer), To (Full address of the person in whose name the service connection stands (or) occupier (or) enjoyer, etc.)</p>	<p style="text-align: center;"><b>FORM 9</b></p> <p>[ Refer Regulation 23 (AA) (8)]  <b>Provisional Assessment order for *theft of energy/Illegal restoration of supply under section 135/138 of the Electricity Act, 2003.</b></p> <p>From (The Authorised Officer), To (Full address of the person in whose name the service connection stands (or) occupier (or) enjoyer, etc.)</p>

<p>Letter No.....,dated.....</p> <p>Sir,</p> <p>Sub: *Theft of energy – Detected in SC No.....Provisional Assessment Order - Reg.</p> <p>Ref: Inspection Report dated ...</p> <p>1.0 On.....(the day, month, year of inspection) at.....(time) hours the service connection in SC No..... located at Door No....., in SF No..... (Full address of the service connection) which is/was in the name of Thiru/Thirumathy ..... was inspected by me in the presence of you/your representative Thiru/Thirumathy .....</p> <p>2.0 * During the inspection it was found that an offence of theft of energy has been committed .....</p> <p>.....</p> <p>(describe the actual mode of theft with details of artificial means found in the service/unauthorized reconnection of a disconnected service connection). By committing the said offence, you have dishonestly abstracted, consumed and used energy with the intention to defraud the licensee.</p> <p>The above said illegal abstraction, consumption and use of energy is punishable under section 135 of the Electricity Act 2003.</p> <p>3.0 The approximate loss caused by you due to dishonest abstraction/illegal restoration of supply is assessed at Rs..... (Rupees ..... ) in accordance with the regulations of the Tamil Nadu Electricity Supply Code, and a working sheet is enclosed herewith.</p> <p>4.0 The assessment amount as referred to above shall be paid within 7 working days from the date of receipt of this order.</p> <p>5.0 If you are desirous of filing objections, if any, against the provisional assessment, you may send your explanation to the address of the undersigned with sufficient proof, within seven days from the date of receipt of this order. You may also choose to appear in</p>	<p>Letter No.....,dated.....</p> <p>Sir,</p> <p>Sub: *Theft of energy /Illegal restoration of supply – Detected in HT/LT SC No.....Tariff.....Provisional Assessment Order - Reg.</p> <p>Ref: Inspection Report dated .....</p> <p>1.0 On.....(the day, month, year of inspection) at.....(time) hours the service connection in SC No..... located at Door No....., in SF No..... (Full address of the service connection) which is/was in the name of Thiru/Thirumathy ..... */and its installation being occupied / used by ..... was inspected by me in the presence of you/your representative Thiru/Thirumathy .....</p> <p>2.0 * During the inspection it was found that an offence of theft of energy/ Illegal restoration of supply has been committed .....</p> <p>.....</p> <p>(describe the actual mode of theft with details of artificial means found in the service/unauthorized reconnection of a disconnected service connection). By committing the said offence, you have dishonestly abstracted, consumed and used energy with the intention to defraud the licensee.</p> <p>The above said illegal abstraction, consumption and use of energy is punishable under section 135/138 of the Electricity Act 2003.</p> <p><b>The service connection was disconnected on the date of detection of above offence.</b></p> <p>3.0 The approximate loss caused by you due to dishonest abstraction/illegal restoration of supply is assessed at Rs..... (Rupees ..... ) in accordance with the regulations of the Tamil Nadu Electricity Supply Code, and a working sheet is enclosed herewith.</p> <p>4.0 The assessment amount as referred to above shall be paid within 7 working days from the date of receipt of this order.</p> <p>5.0 If you are desirous of filing objections, if any, against the provisional assessment, you may send your explanation to the address of the undersigned with sufficient proof, within seven days from the date of receipt of this order. You may also choose to appear in person or through an authorised representative with relevant documents for an enquiry before</p>
---	--

	<p>person or through an authorised representative with relevant documents for an enquiry before the undersigned.</p> <p>6.0 You are requested to acknowledge the receipt of this order immediately.</p> <p style="text-align: center;">Yours <i>Faithfully</i>,</p> <p style="text-align: center;">(Authorised Officer )</p> <p>Encl: Copies of 1. Report 2. Statement Recorded (if any) 3. Mahazar</p> <p>Copy submitted to: .....</p> <p>Copy to He is instructed to arrange to serve this order to the accused person with dated acknowledgement and send the acknowledgement to this office.</p> <p style="text-align: center;">* Strike out whichever is not applicable.</p>	<p><i>the undersigned within 10 days from the date of receipt of this order.</i></p> <p><i>6.0 You are requested to acknowledge the receipt of this order immediately.</i></p> <p style="text-align: center;"><i>Yours Faithfully,</i></p> <p style="text-align: center;"><i>(Authorised Officer )</i></p> <p><i>Encl: Copies of</i> <i>1. Inspection Report</i> <i>2. Statement Recorded (if any)</i> <i>3. Mahazar</i> <i>4. Working sheet as per <b>FORM 8</b></i></p> <p><i>Copy submitted to: .....</i></p> <p><i>Copy to</i> <i>He is instructed to arrange to serve this order to the accused person with dated acknowledgement and send the acknowledgement to this office.</i></p> <p style="text-align: center;"><i>* Strike out whichever is not applicable. (If offence is theft of energy, section 135 is applicable, strike out section 138. If offence is illegal restoration of supply, both section 135 and 138 are applicable.</i></p>
<p>19.</p>	<p style="text-align: center;">Form 10 [ See Regulation 23 (AA) (15)] Final Assessment order for *theft of energy under section 135 of the Electricity Act, 2003.</p> <p>From (The Authorised Officer), To (Full address of the person in whose name the service connection stands (or) occupier (or) enjoyer, etc.)</p> <p>Letter No.....,dated.....</p> <p>Sir, Sub: *Theft of energy– Detected in SC No.....Final Assessment Order - Reg.</p> <p>Ref: 1. Provisional Assessment Order... *2. Your reply....</p> <p style="text-align: center;">***</p> <p>1.0 * On.....(the day, month, year of inspection) at..... (time) hours the service connection SC No..... located at Door</p>	<p style="text-align: center;"><b>FORM 10</b> [ Refer Regulation 23 (AA) (15)] Final Assessment order for *theft of energy/Illegal restoration of supply under section 135/138 of the Electricity Act, 2003.</p> <p>From (The Authorised Officer), To (Full address of the person in whose name the service connection stands (or) occupier (or) enjoyer, etc.)</p> <p>Letter No....., dated.....</p> <p>Sir, Sub: *Theft of energy/Illegal restoration of supply– Detected in HT/LT SC No.....Tariff.....- Final Assessment Order - Reg.</p> <p>Ref: 1. Provisional Assessment Order... *2. Your reply.....</p> <p style="text-align: center;">***</p> <p>1.0 * On.....(the day, month, year of inspection) at..... (time) hours the service connection bearing SC No..... located at Door</p>

<p>No....., in SF No..... (Full address of the service connection) which is/was in the name of Thiru/Thirumathy ..... was inspected by me in the presence of you/your representative Thiru/Thirumathy .....</p> <p>2.0 *During the inspection it was found that an offence of theft of energy/Illegal restoration of supply has been committed .....</p> <p>..... (describe the actual mode of theft with details of artificial means found in the service/unauthorized reconnection of a disconnected service connection). By committing the said offence, you have dishonestly abstracted, consumed and used energy with the intention to defraud the licensee. The above said illegal abstraction, consumption and use of energy is punishable under section 135 of the Electricity Act 2003.</p> <p>3.0 A provisional assessment was issued to you in the reference cited and you were allowed to file your objections and to appear for a hearing as per the Tamil Nadu Electricity Supply Code.</p> <p>4.0 On a detailed examination and on consideration of your explanation offered, facts and records furnished in your letter / during the personal hearing, it is found that the theft of electricity has been committed by you as described below:-</p> <p>(A reasoned/detailed order to be passed by the Officer concerned taking into consideration of the theft of electricity noticed, explanation and the findings, <b>etc.</b>, Reference to be made to the materials in support of the claim of the licensee about the existence of theft, the involvement or the role of the consumer with reference to the said theft of energy, submissions made by the accused person in his written reply as well as during his personal hearing, and reasons for acceptance and rejection of the same ).</p> <p>5.0 * The loss caused by you due to dishonest abstraction/illegal restoration of supply is assessed at Rs.....(Rupees .....) in accordance with the regulations of the Tamil Nadu Electricity Supply Code, and a working sheet is enclosed herewith. This assessment amount referred to above shall be paid within seven working days from the date of receipt of this order.</p>	<p>No....., in SF No..... (Full address of the service connection) which is/was in the name of Thiru/Thirumathy ..... /and its installation being occupied / used by.....was inspected by me in the presence of you/your representative Thiru/Thirumathy .....</p> <p>2.0 *During the inspection it was found that an offence of theft of energy/Illegal restoration of supply has been committed .....</p> <p>..... (describe the actual mode of theft with details of artificial means found in the service/unauthorized reconnection of a disconnected service connection). By committing the said offence, you have dishonestly abstracted, consumed and used energy with the intention to defraud the licensee. The above said illegal abstraction, consumption and use of energy is punishable under section 135/138 of the Electricity Act 2003.</p> <p>3.0 A provisional assessment was issued to you in the reference cited and you were allowed to file your objections and to appear for a hearing as per the Tamil Nadu Electricity Supply Code.</p> <p>4.0 * As you have not made any objection or representation/ On detailed examination and careful consideration of your explanation offered, facts and records furnished in your letter / during the personal hearing, the final order is issued herewith as described below:-</p> <p>(A reasoned/detailed speaking order to be passed by the Officer concerned after thorough analysis of the theft of electricity noticed, inspection report , explanation offered and the findings, <b>etc.</b>, Reference to be made to the materials in support of the claim about the existence of theft, the involvement or the role of the consumer with reference to the said theft of energy, relevant rules and regulations relating to consumers' duty and obligations, submissions made by the accused person in his written reply as well as during his personal hearing, documents/materials submitted by him <b>etc.</b>, and reasons for acceptance and rejection of the same ).</p> <p>5.0 * The loss caused by you due to above explained theft of energy illegal restoration of supply is finally assessed at Rs.....(Rupees .....) in accordance with the regulations of the Tamil Nadu Electricity Supply Code, and a working sheet is enclosed herewith. This final assessment amount shall be paid within seven working days from the date of receipt of this order.</p>
--	--



	<p>You are requested to acknowledge the receipt of this order immediately.</p> <p style="text-align: right;">Yours <b>Faithfully</b>,</p> <p style="text-align: right;">(Authorised Officer )</p> <p>Encl: Copies of 1.Report 2. Statement Recorded (if any) 3. Mahazar 4. Provisional Assessment Order.</p> <p>Copy submitted to: He is instructed to arrange to serve the order to the accused person with dated acknowledgement and send the same to this office.</p>	<p><i>You are requested to acknowledge the receipt of this order immediately.</i></p> <p style="text-align: right;"><i>Yours Faithfully,</i></p> <p style="text-align: right;"><i>(Authorised Officer )</i></p> <p><i>Encl: Copies of</i> <i>1. Inspection Report</i> <i>2. Statement Recorded (if any)</i> <i>3. Mahazar</i> <i>4. Provisional Assessment Order.</i> <i>5. Working sheet as per <b>FORM 8</b></i></p> <p><i>Copy submitted to:</i> <i>He is instructed to serve the order to the accused person with dated acknowledgement and send the same to this office.</i></p> <p><b>* Strike out whichever is not applicable. (If offence is theft of energy, section 135 is applicable, strike out section 138. If offence is illegal restoration of supply, both section 135 and 138 are applicable)</b></p>
<p>20.</p>	<p style="text-align: center;">Form 11 [ see Regulation 23(AA) (22)] Compounding of offence under section 152 of the Electricity Act, 2003.</p> <p>From (The Authorized Officer), To (Full address of the person in whose name the service connection stands (or) occupier (or) enjoyer, etc.)</p> <p>Letter No.....,dated.....</p> <p>Sir,</p> <p style="padding-left: 40px;">Sub: *Theft of energy – Detected in SC No...- Order on Compounding Amount - Reg.</p> <p>1.0 *On.....(the day, month, year of inspection) at.....(time) hours the service connection SC No..... located at Door No....., in SF No..... (Full address of the service connection) which is/was in the name of Thiru/Thirumathy .....was inspected by me in the presence of you/your representative..... Thiru/Thirumathy.....</p> <p>2.0 *During the inspection it was found that an offence of theft of energy has been committed.....</p>	<p style="text-align: center;"><b>FORM 11</b> <b>[ Refer Regulation 23(AA) (22)]</b> Compounding of offence under section 152 of the Electricity Act, 2003.</p> <p>From (The Authorized Officer), To (Full address of the person in whose name the service connection stands (or) occupier (or) enjoyer, etc.)</p> <p>Letter No.....,dated.....</p> <p>Sir,</p> <p style="padding-left: 40px;">Sub: *Theft of energy / Illegal restoration of supply – Detected in HT/LT SC No..... Tariff.....- Order on Compounding Amount - Reg.</p> <p>1.0 *On.....(the day, month, year of inspection) at.....(time) hours the service connection No..... located at Door No....., in SF No..... (Full address of the service connection) which is/was in the name of Thiru/Thirumathy ..... / and its installation being occupied / used by.....was inspected by me in the presence of you/your representative. Thiru/Thirumathy.....</p> <p>2.0 *During the inspection it was found that an offence of theft of energy/ Illegal restoration of supply has been committed.....</p>

	<p>..... (describe the actual mode of theft with details of artificial means found in the service/unauthorized reconnection of a disconnected service connection). By committing the said offence, you have dishonestly abstracted, consumed and used energy with the intention to defraud the licensee.</p> <p>3.0 The above said illegal abstraction, consumption and use of energy is punishable under section 135 / 138 of the Electricity Act 2003.</p> <p>4.0 As you have opted for compounding of offence under section 152 of the Electricity Act, 2003, you are requested to pay Rs..... (Rupees.....) towards the compounding of the offence as mentioned above.</p> <p style="text-align: right;">Yours Faithfully, (Authorized officer)</p> <p>Encl: Working sheet. Copy to</p>	<p><i>(describe the actual mode of theft with details of artificial means found in the service/unauthorized reconnection of a disconnected service connection). By committing the said offence, you have dishonestly abstracted, consumed and used energy with the intention to defraud the licensee.</i></p> <p><i>3.0 The above said illegal abstraction, consumption and use of energy is punishable under section 135 / 138 of the Electricity Act 2003.</i></p> <p><i>4.0 As you have opted for compounding of offence under section 152 of the Electricity Act, 2003, you are requested to pay Rs..... (Rupees.....) towards the compounding of the offence as mentioned above.</i></p> <p style="text-align: right;"><i>Yours Faithfully, (Authorized officer)</i></p> <p><i>Encl: Working sheet. Copy to .....</i></p> <p><b><i>* Strike out whichever is not applicable. (If offence is theft of energy, section 135 is applicable, strike out section 138. If offence is illegal restoration of supply, both section 135 and 138 are applicable )</i></b></p>
<p>21.</p>	<p style="text-align: center;">Form-12</p> <p>Provisional Assessment order for unauthorised use of electricity under section 126 of the Electricity Act, 2003.</p> <p>From To (The Assessment Officer), (Full address of the person in whose name the service connection stands (or) occupier (or) enjoyer, etc.)</p> <p>Letter No.....,dated.....</p> <p>Sir,</p> <p style="padding-left: 40px;">Sub:- Unauthorised use of Electricity detected in HT/LT SC No..... of Tariff No..... - Section 126 of the Electricity Act, 2003 - Issue of Provisional Assessment Order - Reg.</p> <p style="padding-left: 40px;">Ref:- Inspection Report dated .....</p> <p>1.0 *On..... (the day, month, year of inspection) at ..... (time) hours, the electricity service connection No..... located at Door No....., in SF No..... (Full address of the service connection) which is/was in the name of Thiru/Thirumathy .....was inspected by me in the presence of you/your representative Thiru/Thirumathy .....</p>	<p style="text-align: center;"><b>FORM 12</b></p> <p style="text-align: center;"><b>[ Refer Regulation 19(A)(4)]</b></p> <p>Provisional Assessment order for unauthorised use of electricity under section 126 of the Electricity Act, 2003.</p> <p>From To (The Assessment Officer), (Full address of the person in whose name the service connection stands (or) occupier (or) enjoyer, etc.)</p> <p>Letter No.....,dated.....</p> <p>Sir,</p> <p style="padding-left: 40px;">Sub:- Unauthorised use of Electricity detected in HT/LT SC No..... Tariff..... – Section 126 of the Electricity Act, 2003 – Issue of Provisional Assessment Order - Reg.</p> <p style="padding-left: 40px;">Ref:- Inspection Report dated .....</p> <p>1.0 *On..... (the day, month, year of inspection) at ..... (time) hours, the electricity service connection No..... located at Door No....., in SF No..... (Full address of the service connection) which is/was in the name of Thiru/Thirumathy ...../ and its installation being occupied / used by ..... was inspected by me in the presence of you/your representative Thiru/Thirumathy .....</p>

<p>2.0 During the inspection, unauthorised use of electricity was noticed as detailed below:</p> <p>..... ..... (describe the actual mode of unauthorised use of electricity as per the section 126 of the Act). The above said unauthorised use of electricity is punishable under section 126 of the Electricity Act 2003.</p> <p>3.0 A copy of the inspection report is enclosed. A copy of the mahazar prepared at your premises and acknowledgement obtained from you / your representative has already been furnished to you / your representative. A copy of the statement recorded and signed by you / your representative is also enclosed.</p> <p>4.0 You are hereby called upon to stop the said unauthorised use of electricity also remove the equipment used for the said unauthorised use of electricity immediately.</p> <p>5.0 The provisional assessment works out to Rs..... as per the sub-sections (5) and (6) of section 126 of the Electricity Act, 2003. and a working sheet is enclosed. The amount shall be deposited within seven days from the date of receipt of this order, Otherwise, the Service Connection is liable to be disconnected without further notice.</p> <p>6.0 If you are desirous of filing objections, if any, against this provisional assessment, you may send your explanation to the address of the undersigned with sufficient proof, within seven days from the date of receipt of this order. You may also choose to appear in person or through an authorised representative with relevant documents for an enquiry before the undersigned.</p> <p>7.0 If no objection is received from you against this provisional assessment order within the stipulated period or if the objection received is found to be not convincing, further action to pass final order of assessment shall be taken without further notice.</p> <p>8.0 You are requested to acknowledge the receipt of this order with other enclosures immediately.</p> <p style="text-align: right;">Yours Faithfully,</p> <p style="text-align: center;">(Assessment Officer)</p> <p>Encl: Copies of 1. Report 2. Statement Recorded (if any) 3. Mahazar</p>	<p>2.0 During the inspection, unauthorised use of electricity was noticed as detailed below:</p> <p>..... ..... (describe the actual mode of unauthorised use of electricity as per the section 126 of the Act). The above said unauthorised use of electricity is punishable under section 126 of the Electricity Act 2003.</p> <p>3.0 A copy of the inspection report is enclosed. A copy of the mahazar prepared at your premises and acknowledgement obtained from you / your representative has already been furnished to you / your representative. A copy of the statement recorded and signed by you / your representative is also enclosed.</p> <p>4.0 You are hereby called upon to remove the cause of unauthorised use of electricity immediately if not done already and confirm the same by written intimation.</p> <p>5.0 The charges payable by you towards the above unauthorised use of electricity is provisionally assessed at Rs..... as per the sub-sections (5) and (6) of section 126 of the Electricity Act, 2003 and as formulated in FORM 8A of the Supply Code of the Tamil Nadu Electricity Regulatory Commission. The working sheet is enclosed. The amount shall be paid within seven days from the date of receipt of this order, failing which the Service Connection shall become liable to be disconnected.</p> <p>6.0 If you are desirous of filing objections, if any, against this provisional assessment, you may send your explanation to the address of the undersigned with sufficient proof, within seven days from the date of receipt of this order. You may also choose to appear in person or through an authorised representative with relevant documents for an enquiry before the undersigned within the same duration of seven days.</p> <p>7.0 If no objection/ representation is received from you against this provisional assessment order within the stipulated period, the final order of assessment shall be passed accordingly.</p> <p>8.0 You are requested to acknowledge the receipt of this order immediately.</p> <p style="text-align: right;">Yours Faithfully,</p> <p style="text-align: center;">(Assessment Officer)</p> <p>Encl: Copies of 1. Inspection Report 2. Statement Recorded (if any) 3. Mahazar 4. Working sheet as per <b>FORM 8A</b></p>
---	--

	<p>Copy submitted to: .....</p> <p>Copy to: He is instructed to arrange to serve this order to the consumer/occupier/enjoyer with dated acknowledgement and send the acknowledgement to this office.</p>	<p>Copy submitted to: .....</p> <p>Copy to: He is instructed to serve this order to the consumer/occupier/enjoyer with dated acknowledgement and send the acknowledgement to this office.</p>
<p>23.</p>	<p style="text-align: center;"><b>Form-13</b></p> <p>Final order of Assessment for unauthorised use of electricity under section 126 of the Electricity Act, 2003.</p> <p>From (The Assessment Officer), To (Full address of the person in whose name the service connection stands (or) occupier (or) enjoyer, etc.)</p> <p>Letter No.....,dated.....</p> <p>Sir,</p> <p>Sub:- Unauthorised use of Electricity detected in HT/LT SC No..... of Tariff No..... - Section 126 of the Electricity Act, 2003 – Issue of Final Assessment Order - Reg.</p> <p>Ref:- 1. Inspection Report dated ..... *2. Your reply....</p> <p>1.0 On..... (the day, month, year of inspection) at ..... (time) hours, the electricity service connection No..... located at Door No....., in SF No..... (Full address of the service connection) which is/was in the name of Thiru/Thirumathy ..... was inspected by ..... (Designation of the Assessment Officer) in the presence of you/your representative Thiru/Thirumathy .....</p> <p>During the inspection, unauthorised use of electricity was noticed as detailed below: ..... ..... (describe the actual mode of unauthorised use of electricity as per the section 126 of the Act).</p> <p>2.0 A provisional Assessment notice has been issued by the ..... (Designation of the Assessment Officer) vide reference (1) cited above as to why you should not be held liable for the above unauthorised use of electricity and as to why compensation charges should not be levied and collected as per the sub-sections (5) and (6) of the section 126 of the Electricity Act, 2003</p> <p>3.0 On a detailed examination and on consideration of your explanation offered in your letter cited in reference</p>	<p style="text-align: center;"><b>FORM 13</b> <b>( Refer Regulation 19(3) and 19(A)(4))</b></p> <p>Final order of Assessment for unauthorised use of electricity under section 126 of the Electricity Act, 2003.</p> <p>From (The Assessment Officer), To (Full address of the person in whose name the service connection stands (or) occupier (or) enjoyer, etc.)</p> <p>Letter No.....,dated.....</p> <p>Sir,</p> <p>Sub:- Unauthorised use of Electricity detected in HT/LT SC No..... Tariff..... - Section 126 of the Electricity Act, 2003 – Issue of Final Assessment Order - Reg.</p> <p>Ref:- 1. Inspection Report dated ..... *2. Your reply....</p> <p>1.0 On..... (the day, month, year of inspection) at ..... (time) hours, the electricity service connection No..... located at Door No....., in SF No..... (Full address of the service connection) which is/was in the name of Thiru/Thirumathy ..... / *and its installation being occupied / used by ..... was inspected by me in the presence of you/your representative Thiru/Thirumathy .....</p> <p>2.0 During the inspection, unauthorised use of electricity was noticed as detailed below: ..... ..... (describe the actual mode of unauthorised use of electricity as per the section 126 of the Act).</p> <p>3.0 A provisional Assessment order was issued vide reference (1) cited and you were allowed to file your objections if any</p>

<p>(2) and with regard to the facts and records furnished by you, it is found that the unauthorised use of electricity has been committed as described below: (A reasoned/detailed order to be passed by the Officer concerned of taking into consideration the unauthorised use of electricity noticed, inspection report, explanation and the finding. Reference to be made to the materials in support of the claim of the licensee about the existence of any type of irregularities, the involvement or the role of the consumer with reference to the said irregularities unauthorized use of electricity.</p> <p>4.0 The Compensation charges payable by you under sub-sections (5) and (6) of the section 126 of the Electricity Act, 2003 is worked out to Rs..... (Rupees .....only). The detailed working sheet is enclosed herewith. The said amount shall be paid to the TANGEDCO within 30 15 days from the date of receipt of this notice.</p> <p>5.0 In case of default in payment of the assessed amount, the TANGEDCO shall after giving a fifteen days notice in writing, disconnect the supply of electricity.</p> <p>6.0 If you choose to prefer an appeal against this order, you may prefer an appeal in Form 6 of the Tamil Nadu Electricity Supply Code to the appellate authority (Executive Engineer/Superintending Engineer/ Operation .....(address of the appellate authority)) within 30 days from the date of receipt of this order on deposit of half of the assessment amount with the TANGEDCO as per section 127(2) of the Electricity Act, 2003 along with an appeal fee of Rs.100/- by Demand Draft. The Demand Draft shall be drawn in favour of ..... Payable at .....</p>	<p><i>and also to appear for a hearing as per Tamil Nadu Electricity Supply Code.</i></p> <p><i>4.0 * As you have not made any objection or representation/ On detailed examination and careful consideration of your explanation offered in your letter cited in reference (2) and with regard to the facts and records furnished by you, the final order is issued herewith as described below:-</i></p> <p><i>(A reasoned/detailed speaking order to be passed by the Officer concerned after thorough analysis of the unauthorised use of electricity noticed, inspection report, explanation offered and the findings etc., Reference to be made to the materials in support of the claim about the existence of unauthorized use of electricity, the involvement or the role of the consumer with reference to the said unauthorized use of electricity, relevant rules and regulations relating to consumers' duty and obligations, objections made by the consumer in his written reply as well as during his personal hearing, documents/materials submitted by him etc., and reasons for acceptance and rejection of the same ).</i></p> <p><i>5.0 The charges payable by you under sub-sections (5) and (6) of the section 126 of the Electricity Act, 2003 is finally assessed at Rs..... (Rupees .....only). The detailed working sheet is enclosed herewith. The said amount shall be paid within 15 days from the date of receipt of this order, failing which the service connection shall become liable for disconnection on expiry of further fifteen days notice.</i></p> <p><i>6.0 If you choose to prefer an appeal against this order, you may prefer an appeal in Form 6 of the Tamil Nadu Electricity Supply Code to the Appellate authority (Executive Engineer/Superintending Engineer/ Operation .....(address of the Appellate authority)) within 30 days from the date of receipt of this order on deposit of half of the assessment amount with the Licensee as per section 127(2) of the Electricity Act, 2003 along with an appeal fee of Rs.100/- by Demand Draft. The Demand Draft shall be drawn in favour of ..... Payable at .....</i></p>
--	---

<p>7.0 You are requested to acknowledge the receipt of this assessment order with other enclosures immediately.</p> <p style="text-align: right;">Yours Faithfully,  (Assessment Officer)</p> <p>Encl: 1. Report 2. Statement Recorded (if any) 3. Mahazar 4. Provisional Assessment Order.</p> <p>Copy submitted to: He is instructed to arrange to serve the order to the accused person with dated acknowledgement and send the same to this office.</p>	<p>7.0 You are requested to acknowledge the receipt of this Final assessment order immediately.</p> <p style="text-align: right;">Yours Faithfully,  (Assessment Officer)</p> <p>Encl: 1. Inspection Report 2. Statement Recorded (if any) 3. Mahazar 4. Provisional Assessment Order. 5. Working sheet as per <b>FORM 8A</b></p> <p>Copy submitted to: He is instructed to serve the order to the accused person with dated acknowledgement and send the same to this office. <b>* Strike out whichever is not applicable.</b></p>
---	---

(By order of the Tamil Nadu Electricity Regulatory Commission)

-Sd- 26.04.2023

**(Dr.C.VEERAMANI)**

Secretary,

Tamil Nadu Electricity Regulatory Commission.